

FINAL CERTIFICATE OF ANALYSIS



COA N°: 1016312-0
Supersedes:
COA Date: 08/12/2025
Page 1 / 3

Customer: George Municipality
Order N°: PO:2025121_0002975
Client Reference N°:
Project N°: GRJ 25-008577

Analysed By Swift Silliker (Pty) Ltd t/a Mérieux NutriSciences
4 Pearl Street, Tamsui Industrial, George, Western Cape, South Africa
Phone: +27448782218 Fax: +27448730543
E-mail: za.customer@mxns.com

Received from George Municipality

71 York Street, Dormehls Drift, 6530, George, South Africa
E-mail: rwesso@george.gov.za

To: George Municipality
Mr. Randy Wesso
71 York Street Dormehls Drift
6530
George
South Africa

SAMPLE DESCRIPTION

Lab Sample Ref #: GRJ 25-008577-001
Category Detail: Water
Product Description**: Heroldsbay

Sample N°: 6398567
Sample Condition: Sealed

Test Date: 04/12/2025
Date Received: 04/12/2025

ANALYTICAL RESULTS

Tests	Analysis Start Date	Results	Units	Limits [Target value]
☒ Escherichia coli METHOD: SWJM 45	04/12/2025	No Growth	cfu/100ml	Result < 250 cfu/100ml
☒ Intestinal Enterococci (Faecal Streptococci) METHOD: SWJM 57	04/12/2025			
Intestinal Enterococci (Faecal Strep)		1	cfu/100ml	Result < 100 cfu/100ml

SAMPLE DESCRIPTION

Lab Sample Ref #: GRJ 25-008577-002
Category Detail: Water
Product Description**: Gwaing beach

Sample N°: 6398568
Sample Condition: Sealed

Test Date: 04/12/2025
Date Received: 04/12/2025

ANALYTICAL RESULTS

Tests	Analysis Start Date	Results	Units	Limits [Target value]
☒ Escherichia coli METHOD: SWJM 45	04/12/2025	No Growth	cfu/100ml	Result < 250 cfu/100ml
☒ Intestinal Enterococci (Faecal Streptococci) METHOD: SWJM 57	04/12/2025			
Intestinal Enterococci (Faecal Strep)		No Growth	cfu/100ml	Result < 100 cfu/100ml

FINAL CERTIFICATE OF ANALYSIS



COA N°: 1016312-0
Supersedes:
COA Date: 08/12/2025
Page 2 / 3

Customer: George Municipality
Order N°: PO:2025121_0002975
Client Reference N°:
Project N°: GRJ 25-008577

SAMPLE DESCRIPTION

Lab Sample Ref #: GRJ 25-008577-003
Category Detail: Water
Product Description*: Victoria Bay

Sample N°: 6398569
Sample Condition: Sealed

Test Date: 04/12/2025
Date Received: 04/12/2025

ANALYTICAL RESULTS

Tests	Analysis Start Date	Results	Units	Limits [Target value]
☒ Escherichia coli METHOD: SWJM 45	04/12/2025	1	cfu/100ml	Result < 250 cfu/100ml
☒ Intestinal Enterococci (Faecal Streptococci) METHOD: SWJM 57	04/12/2025			
Intestinal Enterococci (Faecal Strep)		3	cfu/100ml	Result < 100 cfu/100ml

SAMPLE DESCRIPTION

Lab Sample Ref #: GRJ 25-008577-004
Category Detail: Water
Product Description*: Wilderness: Salinas

Sample N°: 6398570
Sample Condition: Sealed

Test Date: 04/12/2025
Date Received: 04/12/2025

ANALYTICAL RESULTS

Tests	Analysis Start Date	Results	Units	Limits [Target value]
☒ Escherichia coli METHOD: SWJM 45	04/12/2025	No Growth	cfu/100ml	Result < 250 cfu/100ml
☒ Intestinal Enterococci (Faecal Streptococci) METHOD: SWJM 57	04/12/2025			
Intestinal Enterococci (Faecal Strep)		No Growth	cfu/100ml	Result < 100 cfu/100ml

SAMPLE DESCRIPTION

Lab Sample Ref #: GRJ 25-008577-005
Category Detail: Water
Product Description*: Leentjiesklip

Sample N°: 6398571
Sample Condition: Sealed

Test Date: 04/12/2025
Date Received: 04/12/2025

ANALYTICAL RESULTS

Tests	Analysis Start Date	Results	Units	Limits [Target value]
☒ Escherichia coli METHOD: SWJM 45	04/12/2025	No Growth	cfu/100ml	Result < 250 cfu/100ml
☒ Intestinal Enterococci (Faecal Streptococci) METHOD: SWJM 57	04/12/2025			
Intestinal Enterococci (Faecal Strep)		1	cfu/100ml	Result < 100 cfu/100ml

☒ Accredited analysis

* Non Accredited analysis

➔ Subcontracted Test

NC Non Conformance

** Customer provided data

✍ Changed Data

TMA = Total Microbial Activity / Total Viable Plate Count.

No growth = Not detected / less than the lower detection limit of the test method, for the specified sample type / volume of sample tested.

Tests marked with a tick in this report are included in the SANAS Schedule of Accreditation for this laboratory T0050.

Tests marked with a * in this report are not included in the SANAS Schedule of Accreditation for this laboratory T0050.

** Data provided by the customer.

Tests marked with a plane in this report are Subcontracted Tests and are not included in the SANAS Schedule of Accreditation for this laboratory T0050.

The test report relates only to the specific item submitted for testing. It furnishes or implies no guarantee whatsoever, in respect of a similar item that has not been tested.

The test report applies to the sample as received where the laboratory has not been responsible for the sampling stage.

Opinions and interpretations expressed in this report are not included in the SANAS Schedule of Accreditation for this laboratory T0050.

The test report shall not be reproduced except in full without written approval of Swift Silliker (Pty) Ltd t/a Mérieux NutriSciences.

FINAL CERTIFICATE OF ANALYSIS

COA N°:	1016312-0
Supersedes:	
COA Date:	08/12/2025
Page	3 / 3

Customer:	George Municipality
Order N°:	PO:2025121_0002975
Client Reference N°:	
Project N°:	GRJ 25-008577



Results validated on 08/12/2025

By: Rabi Mpuru

Technical Signatory

A handwritten signature in black ink, appearing to be 'Rabi Mpuru'.