



MINUTES e-BID ADJUDICATION COMMITTEE MEETING 28 NOVEMBER 2025

All Returnable Documents have been evaluated. The tenders listed in the tables below were declared responsive.

Responsive Tenders:

No.	Tenderer	Tender Offer
1.	Lesedi Reticulation (Pty) Ltd	R267,950.00
2.	Samo Engineering	R 298,855.00
3.	RWW Engineering	R 237,398.00
4.	MDL Engineering	R 306,474.00
5.	AM Power Solutions	R 927,383.84

Non-Responsive Tenders:

The following tenders were declared non-compliant, for the reasons indicated below:

No.	Tenderer	Reason(s) for non-responsiveness
1.	Lesedi Reticulation (Pty) Ltd	Did not submit price for Gas Load breakers / Overhead Line Switchgear They do not comply with requirements for Voltage regulators.
2.	Samo Eng Switch Gear	Did not submit price for Gas Load breakers / Overhead Line Switchgear and Voltage regulators.
3.	Mdibi Tours Logistic and Projects	Did not submit information / test certificates as requested on Auto Reclosers. Did not submit price for Gas Load breakers / Overhead Line Switchgear and Voltage regulators.
4.	RWW Engineering	Did not submit price for Gas Load breakers / Overhead Line Switchgear and Voltage regulators.



MINUTES e-BID ADJUDICATION COMMITTEE MEETING 28 NOVEMBER 2025

5.	MDL Engineering	Did not submit price for Gas Load breakers / Overhead Line Switchgear and Voltage regulators.
6.	Teresis (Pty) Ltd	Did not submit information / test certificates as requested on Auto Reclosers and Gas Load breakers / Overhead Line Switchgear. They do not comply with requirements for Voltage regulators.
7.	Mathope Holdings	Did not submit information / test certificates as requested on Auto Reclosers and Gas Load breakers / Overhead Line Switchgear. They do not comply with requirements for Voltage regulators.
8.	AM Power Solutions	Did not submit price for Gas Load breakers / Overhead Line Switchgear. They do not comply with requirements for Voltage regulators.
All tenders received for item 2.1, 12kV Overhead Line Switchgear No award will be made for Item 1.1 until 1.6, 12kV Overhead Line Switchgear, will be re-advertised.		
All tenders received for item 2.2, Voltage Regulator No confirmation could be made, that these prices are market related or not.		

FUNCTIONALITY SCORING

Not applicable to this tender.



ALLOCATION OF POINTS FOR PREFERENCE, PRICE, AND SPECIFIC GOALS: SUPPLY CHAIN SCHEDULE

No.	DESCRIPTION	1.	2.	3.	4.	5.	6.	7.	8.
		Lesedi Reticulation	Samo Eng Switch gear	Mdibi Tours Logistics	RWW Engineering	MDL Electrical	Teresis (Pty) Ltd	Mathope Holdings	AM Power Solutions
1. 12 kV Auto Reclosers									
1.1	12kV Auto Recloser complete as per specification	R 239 200,00	R 292 972,65		R 217 398,00	R 275 568,00			R 195 000,00
1.2	Training for minimum 5 personnel	R 28 750,00	R 5 882,35	NTS	R 20 000,00	R 30 906,00	NTS	NTS	R 1 000,00
	Total as per technical report page 05 (Auto recloser and training must be adjudicated to same service provider.	R267 950,00	R298 855,00		R237 398,00	R306 474,00			R196 000,00
		64.63	52.02		74.10	56.91			94.00
2.1 12kV Overhead Line Switchgear									
1.	2-position, 2-way, manual operation, without integral earthing,	N/Q	N/Q	N/Q	N/Q	N/Q	NTS	NTS	N/Q



MINUTES e-BID ADJUDICATION COMMITTEE MEETING 28 NOVEMBER 2025

2.	3-position, 2-way, manual operation, with integral earthing	N/Q	N/Q	N/Q	N/Q	N/Q	N/Q	N/Q	NTS	NTS	NTS	N/Q
3.	3-position 3-way, manual operation, with integral earthing	N/Q	N/Q	N/Q	N/Q	N/Q	N/Q	N/Q	NTS	NTS	NTS	N/Q
4.	2-position, 2-way, without integral earthing. Motorized and manual local operation. Electrical control cabinet equipped for remote control, but SCADA interface equipment to be supplied by others 3 current transformers in bushings.	N/Q	N/Q	N/Q	N/Q	N/Q	N/Q	N/Q	NTS	NTS	NTS	N/Q



MINUTES e-BID ADJUDICATION COMMITTEE MEETING 28 NOVEMBER 2025

5.	3-position, 2 - way, with integral earthing. Motorized and manual local operation. Electrical control cabinet equipped for remote control, but SCADA interface equipment to be supplied by others 3 current transformers in bushings.	N/Q	N/Q	N/Q	N/Q	NTS	NTS	N/Q
6.	3-position, 3 - way, with integral earthing. Motorized and manual local operation. Electrical control cabinet equipped for	N/Q	N/Q	N/Q	N/Q	NTS	NTS	N/Q



MINUTES e-BID ADJUDICATION COMMITTEE MEETING 28 NOVEMBER 2025

	remote control, but SCADA interface equipment to be supplied by others 3 current transformers in bushings.								
2.2. Voltage regulator									
7.	Voltage regulator 1PH, 11kV, 200A for Delta Operation to Eskom Specifications.	NTS	N/Q	N/Q	N/Q	N/Q	NTS	NTS	NTS