

ANNEXURE I:

*Detailed Design Report for Thembaletu No. 6
Sewer Pump Station*



SMEC INTERNAL REF. C1924

Draft Design Report

Upgrading of Thembaletu No.6 Sewer Pump Station

Client Reference No. Tender T/ING/010/2020

Prepared for George Municipality

27 October 2023

Document Control

Document	Design Report
File Location	P:\C1924_Thembaletu Pumpstation\3_Working\Reports
Project Name	Thembaletu Pumpstation
Project Number	C1924
Revision Number	Revision 0

Revision History

Revision No.	Date	Prepared By	Reviewed By	Approved for Issue By
0	27/10/2023	G Whalley J Fourie B van Niekerk R Pieters T Brink	G Whalley T Kleynhans T Cronje	W Annadale

Issue Register

Distribution List	Date Issued	Number of Copies
George Municipality	20/10/2023	1

SMEC Company Details

Approved by	W Annandale		
Address	13 Progress Street, Dormehlsdrift, George, 6529		
	Western Cape	South Africa	6529
Telephone	+27 44 873 5029	Website	www.smec.com
Email	willem.annadale@smec.com		
Signature			

George Municipality

Approved by	M Geyer		
Address	94 York Street		
	Central		
	George	South Africa	6529
Telephone	+27 44 801 9268		
Email	mgeyer@george.gov.za		
Signature			

The information within this document is and shall remain the property of: SMEC South Africa (Pty) Ltd - George

Important Notice

This report is confidential and is provided solely for the purposes of a Design Report for the abovementioned project for George Municipality. This report is provided pursuant to a Consultancy Agreement between SMEC South Africa (Pty) Ltd ("SMEC") and George Municipality, under which SMEC undertook to perform a specific and limited task for George Municipality. This report is strictly limited to the matters stated in it and subject to the various assumptions, qualifications, and limitations in it and does not apply by implication to other matters. SMEC makes no representation that the scope, assumptions, qualifications, and exclusions set out in this report will be suitable or sufficient for other purposes nor that the content of the report covers all matters which you may regard as material for your purposes.

This report must be read as a whole. The executive summary is not a substitute for this. Any subsequent report must be read in conjunction with this report.

The report supersedes all previous draft or interim reports, whether written or presented orally, before the date of this report. This report has not and will not be updated for events or transactions occurring after the date of the report or any other matters which might have a material effect on its contents, or which come to light after the date of the report. SMEC is not obliged to inform you of any such event, transaction or matter nor to update the report for anything that occurs, or of which SMEC becomes aware, after the date of this report.

Unless expressly agreed otherwise in writing, SMEC does not accept a duty of care or any other legal responsibility whatsoever in relation to this report, or any related enquiries, advice or other work, nor does SMEC make any representation in connection with this report, to any person other than George Municipality. Any other person who receives a draft or a copy of this report (or any part of it) or discusses it (or any part of it) or any related matter with SMEC, does so on the basis that he or she acknowledges and accepts that he or she may not rely on this report nor on any related information or advice given by SMEC for any purpose whatsoever.

Table of Contents

1	Introduction	1
	Terms of Reference	1
1.1	Problem Identification.....	1
1.2	Objectives of this report	2
2	Objectives and scope of the project.....	3
2.1	Employer's Objectives	3
2.2	Scope of Works	3
	2.2.1 Scope of Professional Services	4
	2.2.2 Additional Services	4
2.3	Wayleaves	5
3	Existing System	6
3.1	Earthworks.....	7
3.2	Inlet works	9
3.3	Pump Station	11
3.4	Electrical Infrastructure	12
	3.4.1 Medium Voltage Reticulation	12
	3.4.2 Equipment Room Layouts	12
	3.4.3 Medium Voltage Switchgear	13
	3.4.4 Medium Voltage Power Cable.....	14
	3.4.5 Power Transformer.....	14
	3.4.6 Motor Control Centre.....	15
	3.4.7 Low Voltage Motors.....	15
	3.4.8 Standby Diesel Generator	16
	3.4.9 Telemetry & SCADA.....	17
3.5	Existing rising main	17
4	Detailed Design	21
4.1	Inlet works	21
	4.1.1 Flow Measurement & Sump	21
	4.1.2 Grit Removal.....	22
	4.1.3 Screening.....	23
	4.1.4 Inlet	28
4.2	Pumping Station	28
	4.2.1 System characteristics	28
	4.2.2 Pump Selection	29
	4.2.3 Pipework Optimisation.....	32
	4.2.4 Pump Station Design	32
	4.2.5 Control Philosophy.....	33
	4.2.6 Structures.....	34
4.3	Electrical Load Requirements.....	35
	4.3.1 Background	35
	4.3.2 Phase 1 (Capacity: 238 l/s)	36

4.3.3	Phase 2 (Capacity: 400 l/s).....	36
4.4	Proposed Equipment	37
4.4.1	Medium Voltage Reticulation	37
4.4.2	Equipment Room Layouts	37
4.4.3	Medium Voltage Switchgear	37
4.4.4	Power Transformers	37
4.4.5	Medium Voltage Power Cables.....	38
4.4.6	Low Voltage Switchgear	39
4.4.7	Standby Diesel Generator	41
4.4.8	Telemetry & SCADA.....	42
4.4.9	Earthing and Bonding	43
4.4.10	Building Small Power & Lighting	43
4.5	Rising Main	44
4.5.1	Horizontal Alignment	44
4.5.2	Vertical Profile.....	44
4.5.3	Pipeline Material Selection	44
4.5.4	Water Hammer Analysis	46
4.6	Design Specifications	89
4.6.1	Pipework and fittings.....	89
4.6.2	Associated Infrastructure.....	90
1.1.1.	Stormwater.....	91
4.6.3	Valves, Fittings and Specials	91
4.6.4	Control Assembly.....	93
4.6.5	Corrosion Protection.....	94
5	Operation and Maintenance	95
5.1	Operational and Maintenance Requirements.....	95
5.2	Institutional Training Requirements.....	95
5.3	Cost Recovery Plan.....	95
6	Capital Cost Estimate	96
7	Conclusion and Recommendations	97

Appendices

- Annexure A Pump Station Drawings
- Annexure B Mechanical Drawings
- Annexure C Structural Drawings
- Annexure D Rising Main Drawings
- Annexure E Architectural Finishing Schedule
- Annexure F Architectural Ironmongery Schedule
- Annexure G Architectural Sanitary Schedule

List of Figures

Figure 1-1 Extent of project	2
Figure 3-1: Existing sewer network.....	6
Figure 3-2: Existing terrace section.....	7
Figure 3-3: Existing layout.....	7
Figure 3-4: Photo of existing ground slope and gabions	8
Figure 3-5: Existing mechanical screens.....	9
Figure 3-6: Existing hand rake screens	9
Figure 3-7: Existing ultrasonic flow measurement.....	10
Figure 3-8: Existing pump station electrical rooms.....	11
Figure 3-9: Existing pumps.....	11
Figure 3-10: Existing Single Line Diagram.....	12
Figure 3-11: Existing Equipment Room Layout.....	13
Figure 3-12: Existing Medium Voltage Ring Main Unit.....	13
Figure 3-13: Existing Medium Voltage Metering Unit.....	14
Figure 3-14: Existing Power Transformer No.1 (315kVA)	14
Figure 3-15: Existing LV Motor Control Centre	15
Figure 3-16: Existing LV Motors	16
Figure 3-17: Existing Standby Diesel Generator, ACO Panel & Day Tank.....	16
Figure 3-18: Existing Telemetry & Control Panel	17
Figure 3-19: Existing pipe corridor.....	18
Figure 3-20: Existing pipe bridge.....	18
Figure 3-21: Vandalised bridge	19
Figure 3-22: Stormwater erosion.....	19
Figure 3-23: Stormwater damage.....	20
Figure 3-24: Existing infrastructure on pipe route.....	20
Figure 4-1: Backwater calculation sections.....	21
Figure 4-2: Section of Parshall Flume.....	22
Figure 4-3: Discharge Characteristics of Parshall Flumes	22
Figure 4-4: Grit channel design criteria	23
Figure 4-5: Typical screening loading rates on screens (Metcalf and Eddy Inc., 2003)	25
Figure 4-6: Pump Station System Curve.....	29
Figure 4-7: Phase 1 Pump Curve with Duty Point 1	31
Figure 4-8: Phase 1 Pump Curve with Duty Point 2.....	31
Figure 4-9: Phase 2 Pump Curve with Duty Point 3	32
Figure 4-10: Pump and Pipework layout.....	34
Figure 4-11: Typical Dry-type Transformer (credit: Toshiba)	38
Figure 4-12: Proposed Main LV Incoming Section.....	39
Figure 4-13: Typical MCC Arrangement (credit: Tricom Africa)	40
Figure 4-14: Typical 800kVA Generator General Arrangement (credit: Himoina)	42
Figure 4-15: Pipe fixture on bridge structure.....	45
Figure 4-16: Isometric View of the Pump Stationwith Pipe Diameters.....	47
Figure 4-17: Pump Characteristic Curves.....	48
Figure 4-18: Scenario 1.1 – Maximum Water Hammer Pressure Values.....	50

Figure 4-19: Scenario 1.1 – Minimum Water Hammer Pressure Values.....	51
Figure 4-20: Scenario 1.1 – Maximum and Minimum Water Hammer Grade Line Envelopes	52
Figure 4-21: Scenario 1.1 – Maximum and Minimum Water Hammer Pressures Along Pipeline	53
Figure 4-22: Scenario 1.1 – Air Volume Inside a Strategically Positioned Air Valve	54
Figure 4-23: Scenario 1.1 – Pressure and Flow Directly Downstream of the Pump Station	55
Figure 4-24: Scenario 1.2 – Maximum Water Hammer Pressure Values.....	56
Figure 4-25: Scenario 1.2 – Minimum Water Hammer Pressure Values	57
Figure 4-26: Scenario 1.2 – Maximum and Minimum Water Hammer Grade Line Envelopes.....	58
Figure 4-27: Scenario 1.2 – Maximum and Minimum Water Hammer Pressures Along Pipeline	59
Figure 4-28: Scenario 1.2 – Pressure and Flow Directly Downstream of the Pump Station.....	60
Figure 4-29: Scenario 2.1 – Maximum Water Hammer Pressure Values.....	61
Figure 4-30: Scenario 2.1 – Minimum Water Hammer Pressure Values.....	62
Figure 4-31: Scenario 2.1 – Maximum and Minimum Water Hammer Grade Line Envelopes Along the New Pipeline 63	
Figure 4-32: Scenario 2.1 – Maximum and Minimum Water Hammer Pressures Along the New Pipeline.....	64
Figure 4-33: Scenario 2.1 – Maximum and Minimum Water Hammer Pressures Along the Future Pipeline	65
Figure 4-34: Scenario 2.1 – Air Volume Inside a Strategically Positioned Air Valve Along the New Pipeline	66
Figure 4-35: Scenario 2.1 – Pressure and Flow Directly Downstream of the Pump Station.....	67
Figure 4-36: Scenario 2.2 – Maximum Water Hammer Pressure Values	68
Figure 4-37: Scenario 2.2 – Minimum Water Hammer Pressure Values	69
Figure 4-38: Scenario 2.2 – Maximum and Minimum Water Hammer Grade Line Envelopes Along the New Pipeline 70	
Figure 4-39: Scenario 2.2 – Maximum and Minimum Water Hammer Pressures Along the New Pipeline	71
Figure 4-40: Scenario 2.2 – Pressure and Flow Directly Downstream of the Pump Station	72
Figure 4-41: Scenario 3.1 – Maximum Water Hammer Pressure Values	73
Figure 4-42: Scenario 3.1 – Minimum Water Hammer Pressure Values.....	74
Figure 4-43: Scenario 3.1 – Maximum and Minimum Water Hammer Grade Line Envelopes Along the New Pipeline 75	
Figure 4-44: Scenario 3.1 – Maximum and Minimum Water Hammer Pressures Along the New Pipeline	76
Figure 4-45: Scenario 3.1 – Maximum and Minimum Water Hammer Grade Line Envelopes Along the Future Pipeline 77	
Figure 4-46: Scenario 3.1 – Maximum and Minimum Water Hammer Pressures Along the Future Pipeline	78
Figure 4-47: Scenario 3.1 – Air Volume Inside a Strategically Positioned Air Valve Along the New Pipeline.....	79
Figure 4-48: Scenario 3.1 – Air Volume Inside a Strategically Positioned Air Valve Along the Future Pipeline	80
Figure 4-49: Scenario 3.1 – Pressure and Flow Directly Downstream of the Pump Station.....	81
Figure 4-50: Scenario 3.2 – Maximum Water Hammer Pressure Values	82
Figure 4-51: Scenario 3.2 – Minimum Water Hammer Pressure Values.....	83
Figure 4-52: Scenario 3.2 – Maximum and Minimum Water Hammer Grade Line Envelopes Along the New Pipeline 84	
Figure 4-53: Scenario 3.2 – Maximum and Minimum Water Hammer Pressures Along the New Pipeline	85
Figure 4-54: Scenario 3.2 – Maximum and Minimum Water Hammer Grade Line Envelopes Along the Future Pipeline 86	
Figure 4-55: Scenario 3.2 – Maximum and Minimum Water Hammer Pressures Along the Future Pipeline	87
Figure 4-56: Scenario 3.2 – Pressure and Flow Directly Downstream of the Pump Station	88
Figure 4-57: Scour assembly.....	92
Figure 4-58: Airvalve assembly.....	92
Figure 4-59: Control assembly section	93
Figure 4-60: Control assembly.....	94

List of Tables

Table 4-1: Grit channel design values.....	23
Table 4-2: Grit channel design values	27
Table 4-3: Pump System Characteristics.....	28
Table 4-4: Operational Points Characteristics.....	30
Table 4-5: Operational Points Characteristics	30
Table 4-6: Grit channel design values	32
Table 4-7: Electrical Load Summary (Capacity 180l/s)	36
Table 4-8: Electrical Load Summary (Capacity 400l/s).....	36
Table 4-9: Standard for Earth Rod Dimensions	43
Table 4-10: Standard for Earth Electrode Dimensions	43
Table 4-11: Pump Station Pipe Work Hydraulic Data.....	46
Table 4-12: Force Main Hydraulic Data	49
Table 4-13: Summary of design standards for access roads	90

1 Introduction

Terms of Reference

SMEC South Africa was appointed for a Multi-Year Professional Services Contract (Tender No. TING/010/2020), which includes the upgrade of Municipal Infrastructure by the George Municipality.

The scope of work described in this document is the Design and Implementation of Project 20 (Work Package 1) for the Upgrading of Thembaletu Sewer Pump Station no.6 and the associated rising main.

1.1 Problem Identification

The George Municipality needs to upgrade the existing Thembaletu sewer pumpstation No. 6 and its rising main due to it being hydraulically overloaded. The current capacity of the pumpstation is 60 l/s and needs to be upgraded. The pumpstation will be upgraded to cater for the projected 20-year flow of 238 l/s.

In terms of the sanitation Master Plan of the George Municipality, further upgrades to the pumpstation will be required to cater for the ultimate capacity of 400 l/s as per the George Municipality Sewer Masterplan (GMSMP).

Thembaletu Area 8A & B (Erf 4056 & 4055) is an existing informal community with limited services. The UISP project aims to improve living conditions, reduce the health risk to the residents and the surrounding areas, and allow continued improvement of the surrounding environment via proper management of waste, sewage and stormwater.

The project aims to upgrade / formalise the insitu / existing informal settlement area, as well as provide the necessary internal and bulk services required for the ongoing formalisation of erven through Thembaletu.

The existing Thembaletu bulk sewer system is under stress, with frequent blockages, spillages and leaks resulting in pollution of the Schaapkop River. In addition, the lack of proper sewerage reticulation in the new and proposed formal extensions of Thembaletu UISP (over 4 939 erven) and the proposed Syferfontein Housing Project (7700 erven) will aggravate the situation, and significantly compound the environmental and health problems.

The proposed Thembaletu bulk sewerage infrastructure has been designed to address several of the constraints/problems experienced by the current system and provide the necessary capacity to handle the additional sewage from new and proposed housing developments planned for the area.

The scope of works also includes a new Ø400mm rising main, to be installed parallel to the existing Ø250mm rising main for approximately 700m. The new Ø400mm rising main will be used to convey the future flow of up to 200l/s, with an additional Ø400mm rising main being installed at a later stage to accommodate the ultimate flow requirement of the pump station. The layout of the pump station, therefore, needs to be carefully considered to be compatible with both the current upgrades, as well as future planned upgrades.

Representatives of SMEC and the George Municipality Civil Engineering Services Directorate represented by both Planning, Project Management and Operational personnel walked the site on 08 June 2022 and discussed operational issues currently being experienced.

Figure 1-1 below provides an image from Google Earth which indicates the access road, route of the rising main, pipe bridge, and sewer pumpstation that form part of this project.




Figure 1-1 Extent of project

1.2 Objectives of this report

The objective of this Design Report is to advise the George Municipality of the Design and Detailed cost estimates of this project. This report is based on the conclusions and recommendations from previous planning reports, outcomes of various meetings and discussions with the client, detailed site investigations and visual inspections that were undertaken.

2 Objectives and scope of the project

2.1 Employer's Objectives

The George Municipality has the following objectives:

- Appoint a professional engineering service provider for the upgrade of the existing sewer pumpstation and associated rising main to comply with the current demand and forecasted future demand as set out by the municipal sewer master plan.
- To provide professional engineering services for the upgrade of the existing Thembaletu sewer pumpstation No. 6 and associated rising main ;
- To address all the required planning aspects needed for the project outcomes, including Environmental Authorization, WULA, Survey, Material investigations, and approval from relevant authorities by application of Wayleaves;
- To deliver public services infrastructure using labour-intensive construction methods wherever technically feasible and economically viable;
- To comply with the requirements of the statutory, legislative, and regulatory framework governing local government infrastructure provision; and
- To comply with all funding conditions.

2.2 Scope of Works

The total scope of work for this work package as recommended in the Concept and Viability Report, is outlined below.

Pump station

- Upgrade existing pump station capacity from 60 ℓ/s to 238 ℓ/s (Phase 1)
- Construct two new wet well modules (adjacent to the existing)
- Install three new 134 ℓ/s pump sets in the wet wells. One duty, one assist and one standby pump, rotational basis. (Phase 1)
- Construct a new pump station building to house the three new pumps including an additional for future upgrade of 400 ℓ/s (Phase 2)

Electrical and Electronic

- Install a new 630kVA transformer and upgrade existing 315kVA to a 630kVA, totalling 1.260 kVA
- Replace the existing 350kVA generator with a new 600kVA generator
- Pumps to be equipped with variable-speed drives

Inlet works

- Construct new high-flow inlet works with a capacity of 300 ℓ/s
- Install automated mechanical front rake screens

Rising main

Construct a 700m long, 400mm nominal diameter rising main parallel to the existing rising main (a portion of the pipeline will cross over the existing Schaapkop river pipe bridge which spans 30m in length).

Civil works

- Bulk earthwork and construct a new platform
- Extend the existing gabion retaining wall.
- Construct new concrete retaining walls,
- Extend fencing
- New buildings including guard house, store room, office, and ablution facilities
- Stormwater management at the pump station needs to be linked to that of the access road

2.2.1 Scope of Professional Services

The Scope of Services entails the full scope of services as detailed in ECSA's Guideline for Services and Processes for Estimating Fees for Persons Registered in terms of the Engineering Profession Act, 2000 (Act No. 46 of 2000), and includes the following:

Stage 1: Inception

Stage 2: Concept and Viability

Stage 3: Design Development

Stage 4: Contract Documentation and Procurement

Stage 5: Contract Administration

Stage 6: Close-out

2.2.2 Additional Services

(a) Environmental Considerations

A project of this nature requires an Environmental Impact Assessment (EIA) process to be followed in terms of the National Environmental Management Act (NEMA).

SMEC's appointment includes the design and implementation of a rising main parallel to the existing rising main and the upgrade and improvement to the sewer pumpstation. The flow through the pumpstation and pipeline, liquid (raw sewage) and locality of the infrastructure (construction within 3m of water course and wetland) trigger environmental studies.

The Environmental Impact Assessment (EIA) and Water Use License Application (WULA) were concluded in 2014 and the environmental authorisation is still valid and encompasses all the activities triggered. SMEC will incorporate the terms and conditions of the authorization in the design of the project.

Should the need for an environmental process still be required later during the project, an Environmental Practitioner will be appointed by SMEC using a transparent procurement process consisting of requesting quotations from a minimum of three service providers. Quotations received with recommendations will be presented to the Municipality for acceptance.

(b) Occupational Health and Safety Considerations

The Municipality has appointed a panel of OH&S Representatives. The representative will be included in the design process. The OH&S representative will carry out and build on the Baseline Risk Assessment for the Contract and include monthly audits for the duration of the project. This will be done by analysing the site-specific risks, as well as the proposed design, and being in line with the latest Construction Regulations.

(c) Topographical Survey

Existing survey data is available. Baseline maps of the project area and surrounds showing the location's property boundaries, existing structures, and connections, have been prepared at the onset of the project.

All as-built information available on existing infrastructure pertaining to the site, buildings, inlet works, sumps and associated pumps and pipework including the rising main have been obtained from the Client. This establishes the service interfaces and highlights areas of potential service conflicts. These comprehensive infrastructure service maps will be used throughout the project for the verification of service positions and alignments.

(d) Material Investigation

Previous studies have been undertaken for the initial construction of the pump station. The report will be studied by SMEC.

The available data showed that

- rock refusal has been experienced at depths of 2.5m to 3.7m at the various test pit locations.
- The pipe covers of the new sewer rising main pipe follow the existing rising main profile with varied cover depths of approximately 1 m to 2.5 m below the ground surface. The top layers are a very dense weathered granite which is not suitable for bedding material and allowance from commercial sources has been made in the pricing schedule. Allowance has been made for hard rock excavation for isolated rock outcrops that can be experienced.

2.3 Wayleaves

SMEC has received existing service layouts from service providers and local authority departments. The provided information does not provide the exact locations of the services, but merely a confirmation of their presence.

Before commencing with the works, the Contractor is responsible for obtaining final approval from the local authorities and service providers.

It is anticipated that approval will be required from the following authorities:

- George Municipality
- Sewer infrastructure
- Electrical infrastructure

3 Existing System

The pump station was constructed in 2014 with a capacity of 60ℓ/s. The pumpstation will now be upgraded to handle an interim design flow of 238 ℓ/s, with an ultimate capacity of 400 ℓ/s (GMSMP).

An existing 250mm ND PVC-u Class 16 pipeline accommodates the existing flow from the 60 ℓ/s pump set. The pumpstation is serviced by an existing 315kVA transformer and has a 350kVA generator to supply backup power. The low-flow inlet works are equipped with automated mechanical front rake screens.

The Thembaletu pump station receives sewage from the north by a 315mm diameter HDPE pipe and from the south by a 600mm diameter GRP pipe. Both these currently feed into the existing inlet works.

Flow enters the pumpstation and is divided into two streams, both equipped with mechanical screens and emergency overflow manual screens. The screened sewage passes through grit channels, before passing through a measurement flume and into the wet well of the pumpstation. The pumpstation does not have a balancing dam or emergency storage. The components are discussed in greater detail below.




Figure 3-1: Existing sewer network

3.1 Earthworks

The pump station is constructed on two terraces, cut into the slope. The cut slope is stabilised with a gabion wall structure. The inlet works is positioned on the upper level, from where it drains to the wet well structure. The drywall is positioned on the lower level as can be seen in Figure 3-2. The lower level provides vehicle access to the main structure which houses the electrical infrastructure and equipment.




Figure 3-2: Existing terrace section




Figure 3-3: Existing layout



Figure 3-4: Photo of existing ground slope and gabions

3.2 Inlet works

The existing inlet works have a designed capacity of 100 l/s.

The screening collection system has been removed from the mechanical screens. The team on site informed us that this decision was taken due to them breaking down when the waste collected on them dried and solidified, making it difficult to move and ultimately shearing off the conveyor shaft.

An alternative has been adopted on-site with a perforated dustbin being used to collect the trash directly from the screen. This is an inefficient system with much of the screenings spilling onto the grating and re-entering the liquid stream below, negating the purpose of the screening infrastructure



Figure 3-5: Existing mechanical screens

It was observed on-site that hand-rake screens and additional hanging bars were installed in the grit channels to catch rags and floating materials. This confirms the conclusion about the ineffectual handling of the screenings above or is indicative of the mechanical screens being bypassed or not operating as intended.



Figure 3-6: Existing hand rake screens

The Parshall flume at the end of the inlet works appears to be working correctly with ultrasonic level measurement. Ultrasonic level sensing is taken before and after the mechanical screens to operate the screens.



Figure 3-7: Existing ultrasonic flow measurement

3.3 Pump Station

The previous design made provision for expansion and allowance was made in the electrical buildings for additional equipment. Accordingly, the MCC room, MV room, transformer room, and generator room have all already been provided.



Figure 3-8: Existing pump station electrical rooms

The installed pumps are Gorman Rupp self-priming pumps and are situated above the existing wet well. These pumps are to remain in operation until the new pumps have been installed and commissioned.



Figure 3-9: Existing pumps

3.4 Electrical Infrastructure

3.4.1 Medium Voltage Reticulation

The existing bulk electrical supply to the Thembaletu Pump Station No.6 is reticulated via the George Municipality's medium voltage network, from SS Balottsbai via the "Pro-Ball Lyn Oos" 11kV overhead line infrastructure as indicated in Figure 3-10 below.




Figure 3-10: Existing Single Line Diagram

The supply to the Pump Station is via an 11kV overhead line with an AAAC Mulberry conductor (rated 420A, 8MVA @11kV), which terminates onto a 185mm², Aluminium power cable (rated 265A, 5MVA @11kV) at the pump station. The supply to the pump station is currently a radial supply.

3.4.2 Equipment Room Layouts

Figure 3-12 below shows the existing electrical equipment room layouts at Thembaletu Pump Station No.6. As can be seen from this figure, the equipment rooms have been sized with future expansions in mind. All rooms are very spacious and well-equipped with cable trenches, between the different rooms. This ensures easy installation of electrical equipment and linking of electrical cables between the different equipment.




Figure 3-11: Existing Equipment Room Layout

3.4.3 Medium Voltage Switchgear

Figure 3-12 below shows the existing medium voltage switchgear that is housed in the pump station's MV Room. The MV Switchgear consists of a 3-way Ring Main Unit (CCC-configuration). Each of the contactor circuits is rated at 17.5kV, 630A. The 11kV, 185mm², Aluminium power cable from SS Ballotsbaai terminates onto Incoming Contactor No.1. Contactor No. 2 is supplying the MV Metering Unit. Contactor No.3 is currently not connected. This means that an alternative 11kV source could be connected to this spare feeder to provide a more secure ring feed to the pump station, instead of the current radial supply.



Figure 3-12: Existing Medium Voltage Ring Main Unit

Figure 3-13 below shows the Medium Voltage Metering Unit, which is housed in the same MV Room as the 3-way RMU. As can be seen from the images, the metering unit consists of an incoming cable compartment (from RMU), the main metering compartment (housing the 11kV CTs and VTs) and a circuit breaker compartment, from where the main power transformer for the pump station is being supplied. The circuit breaker compartment is rated 17.5kV, 200A. It is important to note that there is currently only one (1) transformer feeder, supplying the existing 315kVA transformer. There is, however, sufficient space next to the existing transformer feeder to add an additional feeder to supply a second transformer.



Figure 3-13: Existing Medium Voltage Metering Unit

3.4.4 Medium Voltage Power Cable

Although it could not physically be confirmed on site, it can be seen from the existing single line diagram (Figure 3-10), that an 11kV, 25mm², Copper power cable is used between the MV Metering Unit and the main power transformer. This cable is rated 115A, 2.2MVA @11kV when installed in ducts/trenches.

3.4.5 Power Transformer

The existing power transformer is shown in the figure below. As can be seen from these images, this transformer is housed in the dedicated transformer room. This transformer room is big enough to accommodate a second transformer in the future (if required).



Figure 3-14: Existing Power Transformer No.1 (315kVA)

From the transformer nameplate data, the following could be established:

Output kVA:	315kVA
Ratio:	11000/400 V
Cooling:	ONAN
Vector Group:	Dyn11
Year of Manufacture:	2012

3.4.6 Motor Control Centre

Figure 3-15 below shows the existing LV Motor Control Centre. This MCC is positioned against the northern wall of the existing MCC Room at the pump station. The MCC was manufactured in 2012 and has a busbar rating of 400A @ 400V (276kVA), with a fault withstand capability of 30kA for 1 second.



Figure 3-15: Existing LV Motor Control Centre

The current MCC layout makes provision for the following functional units:

1. Main incoming
2. Local distribution
3. Control section: mechanical screen 1
4. Control section: mechanical screen 2
5. Control section: screw conveyor 1
6. Control section: screw conveyor 2
7. Control section: sewage pump 1
8. Control section: sewage pump 2
9. Local control section
10. Wireways & distribution terminals

The screw conveyor and mechanical screens have been equipped with WEG CFW-11 variable frequency drives, whilst the two (2) sewage pumps are started via WEG SSW-06 soft starters.

All power and control cables are bottom entry via cable trenches and neatly managed between the MCC and the motors using heavy-duty cable racks, mounted against the walls.

3.4.7 Low Voltage Motors

The existing sewage pump motors are shown in Figure 3-16 below. These motors are both rated 75kW @400V, with a power factor of 0.87. The motors are currently operated in a 1x duty, 1x standby configuration.



Figure 3-16: Existing LV Motors

3.4.8 Standby Diesel Generator

The images below provide an overview of the existing standby diesel generator installation for the pump station.



Figure 3-17: Existing Standby Diesel Generator, ACO Panel & Day Tank

From the generator nameplate data, the following could be established:

- Output kVA (continuous): 403kVA

- Output Voltage: 400 V
- Power Factor: 0.8
- Insulation: Class H
- Speed: 1500 rpm

The generator is housed in a dedicated generator room (also indicated in Figure 3-11). The room is well-ventilated with louvered wall sheets, with a dedicated air inlet in front of the machine. The generator is supplied from an external (underground) bulk fuel tank of which the capacity could not be determined from the site or existing drawings. The diesel is then pumped into a day-tank, which is installed inside the generator room (refer to Figure 3-17 above).

The standby diesel generator is also equipped with an Automatic Change-over (ACO) Panel system, which senses the loss of the Mains Supply, automatically starts the diesel engine and transfers the load to standby power. The same sequence is also reversed when the normal power is restored. The existing contactors on the ACO panel are rated 500A and 400V, which means that they are only sized for the current generator capacity.

3.4.9 Telemetry & SCADA

The images below provide an overview of the existing telemetry and SCADA control equipment installed for the pump station. As can be seen from these images, the existing MCC has a control panel, which houses a Spectrum Teleflex 5, that acts as both controller and Telemetry RTU and has an HMI display on the door of the panel.

There is also communication equipment installed, which interfaces with the municipality's master SCADA system for remote monitoring and control functionality.



Figure 3-18: Existing Telemetry & Control Panel

3.5 Existing rising main

The existing rising main is indicated to be a 250mm diameter U_PVC of class 16 which accommodates the existing flow of 60 ℓ/s . The pipe route follows the service corridor which has been prepared to accommodate the pipe route. The existing 250mm diameter pipe with associated infrastructure is located within the service corridor. The pipeline crosses over the Schaapkop river with a steel structure pipe bridge. Figure 3-19 shows the corridor with stormwater infrastructure in the background.



Figure 3-19: Existing pipe corridor

The pipe route follows the corridor up the crossing of the river, where a street carrier bridge was constructed. The bridge structure is crossed with a ductile iron pipe. The image below shows the bridge structure. It was noted that some vandalism has occurred and that remedial actions will be required.



Figure 3-20: Existing pipe bridge



Figure 3-21: Vandalised bridge

The existing pipe route shows some signs of erosion which may pose a risk to the pipe construction if left unprotected.



Figure 3-22: Stormwater erosion



Figure 3-23: Stormwater damage

Existing chambers along the existing pipe route what seems to be a scour valve seem to be still in tack and structurally sound as seen in Figure 3-24 below.



Figure 3-24: Existing infrastructure on pipe route

4 Detailed Design

During the design phase, careful consideration was given to safety, leak and damage prevention, government regulations and environmental concerns. As far as reasonably practicable, interruption to the operations of the existing works will be avoided with minimal downtime for cross-connection of the existing and new works.

4.1 Inlet works

The new inlet structure will consist of flow division into 2 streams, manual coarse screening, mechanical screening with emergency screen bypass, grit channels, and flume measurement.

The hydraulic design calculations of the inlet works were done by means of hydraulically calculating the backwater curve to determine the flow depth and velocity throughout the inlet works; as such, the first section calculated was the end of the inlet works and then moving upstream.




Figure 4-1: Backwater calculation sections

The new inlet works will be sized to handle the anticipated flows for the initial period after the upgrade. Thus, the refurbishment of the existing inlet works can be performed. Both inlet works (new and refurbished) will be required to accommodate the ultimate design flows.

4.1.1 Flow Measurement & Sump

The Parshall flume size was selected as a 1-foot flume. This was done for a number of reasons.

- The flow depth can accommodate the largest range of flows
- The discharge rate that can be accommodated encompasses all flows that would be expected
- The correction factor for submerged conditions is 1 which does not alter the flow calculations in the event that the flume is flooded

Flows from the existing inlet works will discharge into a combined sump with the flows from the new inlet works (each having been measured through their respective flumes), from where it will discharge via a DN500 pipeline equipped with an isolation valve. The depth of the sump is such that the Parshall flume can have a free-flow discharge and not cause any backwater pressure which would affect the measurement readings.




Figure 4-2: Section of Parshall Flume

Throat width b_c in feet or inches	Discharge range in $m^3/s \times 10^{-3}$		Equation $Q = K h_a^u$ (Q in m^3/s)	Head range in metres		Modular limit h_b/h_a
	minimum	maximum		minimum	maximum	
1"	0.09	5.4	$0.0604 h_a^{1.55}$	0.015	0.21	0.50
2"	0.18	13.2	$0.1207 h_a^{1.55}$	0.015	0.24	0.50
3"	0.77	32.1	$0.1771 h_a^{1.55}$	0.03	0.33	0.50
6"	1.50	111	$0.3812 h_a^{1.58}$	0.03	0.45	0.60
9"	2.50	251	$0.5354 h_a^{1.53}$	0.03	0.61	0.60
1'	3.32	457	$0.6909 h_a^{1.522}$	0.03	0.76	0.70
1'6"	4.80	695	$1.056 h_a^{1.538}$	0.03	0.76	0.70
2'	12.1	937	$1.428 h_a^{1.550}$	0.046	0.76	0.70
3'	17.6	1427	$2.184 h_a^{1.566}$	0.046	0.76	0.70
4'	35.8	1923	$2.953 h_a^{1.578}$	0.06	0.76	0.70
5'	44.1	2424	$3.732 h_a^{1.587}$	0.06	0.76	0.70
6'	74.1	2929	$4.519 h_a^{1.595}$	0.076	0.76	0.70
7'	85.8	3438	$5.312 h_a^{1.601}$	0.076	0.76	0.70
8'	97.2	3949	$6.112 h_a^{1.607}$	0.076	0.76	0.70

Figure 4-3: Discharge Characteristics of Parshall Flumes

4.1.2 Grit Removal

For grit removal, the determining factors are the settling velocity and retention time. The table below gives guidelines on the design of the grit channels.

Design Criteria	Range	Typical
Detention time	40 – 90 s	60 s
Horizontal velocity	0.24 – 0.4 m/s	0.3 m/s
Settling velocity		
50-mesh	2.8 – 3.1 m/min	2.9 m/min
100-mesh	0.6 – 0.9 m/min	0.8 m/min
Headloss (% of channel depth)	30 – 40%	36%
Inlet and outlet length allowance	25 – 50%	30%

If the specific gravity of the grit is significantly less than 2.65, lower velocities should be used.

Figure 4-4: Grit channel design criteria

A robust approach was opted for in order to be able to meet the worst possible conditions experienced in the grit channels. Table 4-1 below provides the design values used to determine the sizing of the grit channels. With 2 channels operational and one on standby, there is redundancy that allows for cleaning the channel that is not in use to ensure full capacity is available at all times. A side chamber is provided to assist with flushing the channel, not in operation. This is done by closing the gates at either end of the channel and opening the drainage valve to the side chamber so that all the liquid dissipates from the channel – the channel can then be cleaned with a spade to remove all the solid material left behind. The bottom width of the channel was sized to be able to accommodate a spade for ease of cleaning.

Table 4-1: Grit channel design values

Criteria	Units	Value
Flow	m ³ /s	0.3
# of channels operational	-	2
Width of channel	m	1
Depth of channel	m	0.9
Area of water	m ²	1.53
Horizontal velocity	m/s	0.196
Vertical velocity (settlement)	m/s	0.016
Time for the particle to settle	seconds	56.25
Horizontal distance travelled	m	11.03

With a channel length of 11m, at maximum flow, the retention time in the channels will be just less than 1 minute which is typical despite the horizontal velocity being lower than the typical range.

4.1.3 Screening

There will be two screening trains, each with an automated mechanical bar screen, a coarse manual bar rake screen upstream of the automated screen, and a fine manual bar rake screen downstream of the automated screen.

Each screen will have a bypass channel in the event of a screen being blocked, allowing sewage to bypass the specific screen and re-enter the screening channel directly downstream of the blocked screen.

Each screening train shall be designed to handle the full design flow rate and solids loads.

The channels for screening were designed to be the same as the existing inlet works. The advantages of using the same screens will reduce the number of spare parts to be kept as all screens will be the same.

New automated mechanical screens, hand rake screens, screw conveyors and washer compactors will be installed in the new screening channels.

The sizing of the screening channels was done such that the velocity did not drop below 0.6m/s which would allow for settlement and thus self-cleaning can be maintained by the flow through the screen channels.

Sluice gates are provided upstream and downstream of the screens as well as upstream and downstream of the grit channels to allow for the selection of any of the channels to be used or isolated in the operation while allowing enough transition space for the water to flow and not become stagnant. The screens have been sized with the following sizes:

- 50mm hand rake screen (protection of the mechanical screen from large objects)
- 10mm mechanical screen (intended to remove the majority of the solids in suspension)
- 6mm hand rake screen (catchment for any finer particles and a failsafe in the event of the mechanical screen not being operational)

(a) Screening Equipment

Manual Hand Rake Bar Screens:

The screens shall be the flat bar type bar screens. The hand-rake screens in the main channels prior to the automated mechanical screen shall be sized to catch large objects that pose a risk of damage to the automated screens, therefore a bar spacing of 50 mm is used. The hand-rake screens in the main channels after the automated mechanical screen shall be sized to catch finer particles and will have a 6mm bar spacing. The angle of the bars shall be 60 °to the channel floor and the minimum bar thickness would be 10 mm. The screens shall span over the entire width of the respective channels.

All screens shall be completely manufactured from 316-grade Stainless Steel to ensure the longevity of the equipment. Specifically sized hand rakes to suit the bar spacing of the types of screens shall be provided. Each screen shall have a removable drainage platform onto which the debris can be raked to drain excess liquid before the debris is transferred to the waste skip by means of a shovel. The drainage platform shall be removable to allow access to the channel for maintenance work.

The George Municipality accepted the associated labour-intensive operation to clean the screens and transfer the debris to the skips in meetings held during the design stage.

Automated Mechanical Bar Front-Rake Screen

The automated screens will be of the front rake type and each screen train shall be sized to handle the full design flow. Due to the high number of rags in the sewage, medium screens with 10 mm bar spacing are proposed.

The automated screens are positioned in adjacent channels as this is the most efficient setup for the waste removal system and still allows sufficient space for operators to move around within the facility and have full access to the bypass channel (should it be needed). Sufficient space has also been allowed between the units for day-to-day operational access and maintenance.

The automated mechanical screens are estimated to handle an average solid loading of $\pm 0.098 \text{ m}^3/\text{h}$ (based on an assumed 50 L screenings removed from 1000 m^3 sewage with a 10 mm screen opening and 35 % excess over the maximum expected solids loading of the sewage as per Figure 4-5) under peak conditions.

Table 5-2 Typical information on the characteristics and quantities of screenings removed from wastewater with coarse screens	Size of opening between bars, mm	Moisture content, %	Specific weight, kg/m ³	Volume of screenings			
				ft ³ /Mgal		L/1000 m ³	
				Range	Typical	Range	Typical
	6.0*	60-90	700-1100	7-13.5	9.5	51-100	67
	12.5	60-90	700-1100	5-10	7.0	37-74	50
	25.0	50-80	600-1000	2-5	3.0	15-37	22
	37.5	50-80	600-1000	1-2	1.5	7-15	11
	50.0	50-80	600-1000	0.5-1.5	0.8	4-11	6

* Information on line screen added for the purpose of comparison.
 Note: mm $\times$ 0.3937 = in.
 kg/m³ $\times$ 8.3497 = lb/1000 gal.

Figure 4-5: Typical screening loading rates on screens (Metcalf and Eddy Inc., 2003)

The above typical information is not based on the South Africa environment and therefore, as a minimum, the equipment should be sized to handle at least 4 m³/h to ensure the longevity of equipment and be in line with the expected loading as discussed in section 2.3. Each screen shall at least have 8 rakes to lower the volume of debris handled per rake. The material of construction shall be selected for highly corrosive environments and South African sewage characteristics, therefore as a minimum grade 316 Stainless Steel shall be used on all components, including the chains and sprockets.

The mechanical screen frame sizes shall be designed to reach the screw conveyor situated at roughly 1.5-2.0 m above ground level, with a specially manufactured diversion chute between the screen discharge point and the screw conveyor hopper.

General maintenance is required on the mechanical screens and components based on the OEM's requirements, therefore items such as the gearboxes, motors, drive shafts, bearings and chain tensioners must be easily accessible for maintenance and the relevant equipment put in place to remove components when required. The screen's inherent design allows for access to wear or serviceable parts for general maintenance to be completed, without the need to remove the entire screen unit.

The space available between the channels is an issue, only a wall thickness of 200 mm is available. This does not allow for sufficient space to work on the screens during maintenance or repairs. It will also mean that the mechanical screens placed adjacent to one another will have to be configured with the drive unit on opposite sides to enable - the unit to be installed in adjacent channels.

(b) Waste Removal Equipment

For the proposed layout, screened debris from the manual hand rake screens would be removed by the operator and transported to the skip adjacent to the screening facility. The operator would rake the debris caught by the manual hand rake screens on to the respective drainage platforms where the excess liquid can drain from the debris. Large objects can be transported to the waste skip by hand or by means of a shovel. Smaller objects can be transported to and deposit into the screw conveyor (servicing the automated mechanical screens) through the hatch provided that will transfer the debris to the washer compactor unit to clean and compact it.

Sufficient working space is provided for the operator to do the daily duties of cleaning the screens.

Two trains of waste removal equipment will be installed, each with a screw conveyor and washer compactor. Screened debris from the automated mechanical screens is deposited into a specially manufactured chute per screen which will direct screenings into either the screw conveyors, from where two screw conveyors then transport the debris to a washer-compactor unit where the matter is cleaned, dried, and compacted for removal. The specially manufactured chute is to ensure redundancy in case one of the conveyors or washer compactors is out of order. Once this wash and dry process is complete, the washer compactors deposit the materials into a skip, mounted on a dolly system.

Screw Conveyor

The screw conveyor for the automated mechanical screens shall be of the centreless screw type, driven by a geared electrical motor. The conveyor shall be sized to handle at least 3.5 m³/h to ensure the longevity and robustness of the unit. The resulting minimum screw size is DN300 and is driven by a 4kW motor.

Each automated mechanical screen shall have a specially manufactured chute that will be able to divert screenings from each screen to either of the two screw conveyors. The chute shall be operated manually by means of a lever.

Each screw conveyor unit shall have three inline hoppers, two hoppers to receive the debris from the two automated screens and one hopper with a hatch that is used for the debris deposited by the operator that was removed from the manual hand rake screen. The conveyor will be supported by legs to handle all static and dynamic forces.

The complete unit, including the screw shall be manufactured from 316-grade Stainless Steel and the through will have a double colour UHMWPE liner.

General maintenance is required on the equipment and components based on the OEM's guidelines, therefore items such as the gearboxes, motors, drive shafts and bearings must be easily accessible for maintenance and the relevant equipment put in place to remove components when required. The conveyor's inherent design allows for access to wear or serviceable parts for general maintenance to be completed, without the need to remove the entire unit/s.

Washer Compactor

The washer compactor shall be of the shafted intensive type with a forced washing mechanism by means of an impeller. The unit shall have a washing compartment that fills with water and the debris and water are agitated by means of a motor-driven impeller to separate the organic particles from the debris. Once the washing cycle is complete, the compartment will be drained via the drain valve and drain pipework back to the screening channels. The washed debris will be compacted by a screw to reduce the liquid content and reduce the volume and conveyed to the discharge chute. The compacted debris will be deposited into a waste skip positioned adjacent to the screening channels.

The unit shall be sized to handle a minimum of 3.5 m³/h debris (batch processing) and the complete unit, including the compacting screw, shall be manufactured from 316-grade Stainless Steel.

The unit shall be equipped with a suitable solenoid discharge valve to drain the water after the washing cycle and during the compacting cycle. The drainage pipework would be suitably sized DN100 pipework (according to SANS 62) and flanged according to SANS 1123. The pipe work shall be manufactured from 316-grade Stainless Steel and shall be properly supported by means of clamps.

The unit requires a wash water connection for the filling of the wash compartment. Due to no available treated effluent available on the site, potable water is proposed from the Municipal network. The wash water supply of 1.2 L/s at 2-3 bar is required for intermittent operation. The associated supply pipework from an onsite point to the washer compactor will be installed as part of the project.

General maintenance is required on the equipment and components based on the OEM's requirements, therefore items such as the gearboxes, motors, drive shafts and bearings must be easily accessible for maintenance and the relevant equipment put in place to remove components when required. The washer compactor's inherent design allows for access to wear or serviceable parts for general maintenance to be completed, without the need to remove the entire unit/s.

Skip Dolly System

The dolly system, driven by an electrical motor (manual start intervention by the operator) will house a single skip and shall transport the skip away from the washer-compactor discharge chute, to be removed from the site with a truck. A minimum skip size of 6 m³ is recommended to prevent a high turn around frequency. The layout allows for a dolly system that would allow for two skips to be placed on two dollies, linked together operating. The supply of skips would not be part of the project, however, the Municipality shall make use of existing service level agreements to provide and service the skips.

The skips would work on a one-duty and one-standby configuration. The dolly could be moved closer to the common channel while still receiving debris from the washer-compactor should a crane truck need to access the area for maintenance.

The dolly rails would be recessed into the concrete slab on request of George Municipality to enable vehicles to pass over it with ease. The dolly rails shall be a standard rail profile of a minimum of 22 kg/m and shall be used to suit the weight of the dolly system. The dolly shall be manufactured from hot dipped galvanised and coated mild steel and driven by an electrical geared motor. It must be noted that dolly rails and channels must be kept clean and dried to prevent premature corrosion and ensure maximum longevity.

(c) Ancillary Equipment

Penstocks

Four penstocks will be installed in the screening channels and will be equipped with suitable-sized multi-turn electrical actuators for open/close function for ease of operation. Actuators such as Auma / Rotork rated at ± 5.5 kW would be considered with the suitable network communication to the MCC. The penstocks upstream of the screening channels have a width and height of 600 mm and 1100mm respectively. The penstocks downstream of the screening channels have a width and height of 600 mm and 1250mm respectively.

Six penstocks will be installed in the degritting channels and will be equipped with suitably sized multi-turn electrical actuators for open/close function for ease of operation. Actuators such as Auma / Rotork rated at ± 5.5 kW would be considered with the suitable network communication to the MCC. The penstocks have a width and height of 1000 mm and 1000mm respectively.

Wash Water Requirements

Suitable wash water would be required for the operation of the washer compactor. As stated previously, treated effluent is not available on-site and therefore potable water from the Municipal network would be used for the above operation and general wash-down actions by the operators.

A mobile, high-pressure washing system is recommended so that the area can routinely and easily be cleaned and washed down, of which the run-off is contained and diverted back into the sewage canals. The washer would be connected to the water network and rated for at least 840 l/min at 130 bars.

A suitable connection to the onsite potable water network would be made and distributed to the respective areas where it is required. In Table 2 below, an estimate is made on the amount of water to be used by the respective processes:

Table 4-2: Grit channel design values

Process	Flow Required	Estimated Frequency	Estimated Total per Month (30 days)
Washer compactor	4.2 m ³ /h (1.2 L/s)	10 min at 2-hour intervals	252 m ³
Manual cleaning operations (high-pressure washer)	0.9 m ³ /h (0.25 L/s)	8 hours per week	31 m ³
Estimated Total			283 m ³

Note that the frequency of use is estimated and would depend on the frequency of the automated screen cleaning cycles and the frequency/duration of operator cleaning operations.

4.1.4 Inlet

Similar to the existing inlet works, the inlet acts as a collection sump and splitter before the screening channels. The question was asked whether a macerator would be beneficial at this location. Upon review, it is the opinion of the design team that a macerator would not be suitable for this application; the macerator is used to reduce the particle size, however, this only serves to make the screening more difficult as the screens are required to capture smaller object sizes and they are more likely to not be captured before pumping, and will increase the volume of sludge generated and requiring handling is at the waste water treatment plant. As this site is primarily for pumping of the wastewater, and treatment of the wastewater will take place at another location, the use of a macerator is not suggested and thus has not been included in this design.

4.2 Pumping Station

SMEC completed the sewer pump station building and pipework design, which was based on the various investigations, the site visual assessment, provided pipe diameters and flows by GLS, EIA and WULA requirements and the connectivity to the existing sewerage system.

The design takes into consideration the previously proposed pump station design with provision being made for the proposed expansion of the pump station capacity at a later stage.

Pumps and piping:

The pump and pipe sizing have been designed with the information including projected future flows obtained from the approved GLS report. The static head, friction losses and transient event pressures were considered in the pump sizing.

Building Infrastructure:

The design has been based on best practices, taking into consideration the current infrastructure and proposed pump station layout and requirements, making provision for the further expansion of the pump station at a later stage. The building size is based on the pumps and mechanical arrangements required to fit within the building for the final capacity, along with the generators and transformers chosen for the final approved design. The layout of the building allows sufficient space and specific connection points to accommodate future expansion in this design. Additional components such as washrooms, ablutions, a control room, and a guardhouse have also been considered to ensure a holistic design of the pump station.

4.2.1 System characteristics

The design of the pumping system is dependent on the system characteristics and the connections to the existing infrastructure. The existing sump will be used (and duplicated with the same dimensions and levels) and the discharge point will remain the same which determines the static head required. The pipeline will follow the same route as the existing pipeline; thus, the pipe length is already known. The pipeline diameter is selected to be able to meet the current and future demands and from this determination the friction losses are determined, giving the total required head. The pump is then selected based on the flow and head requirements, which then determines the required impeller diameter and pump motor sizes.

The table below summarizes the key system characteristics:

Table 4-3: Pump System Characteristics

Description	Data
Maximum Water Level in Sump	116.1 m
Minimum Water Level in Sump	114.0 m
Discharge Level	165.2 m
Minimum Static Head	49.1 m
Maximum Static Head	51.2 m
Pipe Length	710 m

Suction Pipe Size and Type	450 mm Ø Steel Grade 316
Delivery Pipe Size and Type	350 mm Ø Steel Grade 316
Delivery Pipe Size and Type	400 mm Ø OPVC

The system curve is shown in the below figure:



Figure 4-6: Pump Station System Curve

4.2.2 Pump Selection

The proposed pumps of Thembaletu 6 pump station are selected in line with the information obtained from the GLS report.

The current capacity of the pump station is to be upgraded to accommodate the next estimated flow for the next 20 years of 238 l/s. In terms of the sanitation master plan of the George Municipality, further upgrades to the pump station will need to be carried out in the future to cater for the ultimate capacity of 400 l/s.

Mechanical equipment has an acceptable lifespan of 15 - 20 years thus it is recommended that the initial pump station capacity should allow for 238 l/s until the 20-year sanitation master plan horizon, at which time the pump station's capacity can be upgraded in conjunction with refurbishment/replacement of the existing mechanical equipment.

It is recommended that the capacity upgrade is achieved by adding an additional pump set, that is equivalent/identical to the initial pump set installed, with the addition of a self-priming system being installed on the pumps, and the start level of the pumps lowered to ensure the maximum number of pumps starts per hour is not met.

A minimum flow rate of 90 l/s and 180 l/s is recommended to ensure self-cleansing velocities are achieved in the rising main for a single and a double DN400mm rising main(s) respectively. It is recommended that a variable speed drive is installed to operate the pumps to allow the pumps' speed to be reduced to meet the lower duty points.

To ensure adequate redundancy in the pumping system, it is recommended that there be at least one standby pump provided at any point to achieve the required flow rate.

A number of reputable dry-installed sewage pump suppliers were requested to provide their proposed pump configurations and selections to achieve the different system flow rates. Different configurations were evaluated, ranging from a single-duty pump to achieve the ultimate flow rate of 400 l/s, to three identical pumps in parallel able to meet the 400 l/s in parallel. The three-duty pump configuration has been selected as it offers the widest flow ranges able to be met in the current phase, with the option of adding an additional pump in the future to meet the ultimate flow requirement. All the suppliers recommended end-suction centrifugal pumps. Three pumps will be installed during the initial phase, as a duty-assist-standby configuration.

Phase 1 (238 l/s):

To minimise the complexity of the pumping system, it is not recommended to PID on the level in the wet well, but rather to start the pumps sequentially depending on the level in the wet well. There will thus be two start levels in the wet well, with one pump operating at a set speed and flow on the first start level, and two pumps operating at a set speed and flow on the second start level. The levels in the wet well are set such that the effective pumping volume is sufficient to ensure the pumps do not operate more than six (6) cycles per hour and allow enough volume for pumps to speed up to meet their operational set point prior to reaching any other level set points in the sump such as the next start level or high level.

To ensure sufficient effective pumping volume in the wet well for the ultimate pumping capacity of 400 l/s, the pumps installed under the first phase shall be capable of being adapted to be a self-priming pump, with the self-

priming system being installed under the second phase of the project when refurbishment/replacement of the mechanical equipment is required.

On the first start level, one pump shall operate at the manufacturer's minimum recommended flow rate, which in this case is 125 l/s. On the second start level, two pumps in parallel shall operate at a combined flow of 238 l/s.

The table below summarizes the key operational points of the pumps:

Table 4-4: Operational Points Characteristics

Duty Point	Description	Data
1	1 x Duty Pumping Flow Rate	125 l/s
	1 x Duty Pumping Head	53.0 m
	1 x Duty Operating Speed	1427 RPM
2	2 x Duty Pumping Flow Rate	119 l/s
	2 x Duty Pumping Flow Rate (Combined)	238 l/s
	2 x Duty Pumping Head	59.0 m
	2 x Duty Operating Speed	1476 RPM

Phase 2 (400 l/s):

A self-priming system will be required at the upgrade of the pump station to the ultimate capacity to allow for sufficient effective pumping volume. The start level shall be set to the minimum draw-down level based on the pump NPSH and minimum submergence of the suction pipe, which is below the pump's suction port. In line with this, the pumps shall be configured to operate as 3 x duty, with an additional pump being installed as a standby.

The table below summarizes the key operational points of the pumps:

Table 4-5: Operational Points Characteristics

Duty Point	Description	Data
3	3 x Duty Pumping Flow Rate	134 l/s
	3 x Duty Pumping Flow Rate (Combined)	400 l/s
	3 x Duty Pumping Head	55.0 m
	3 x Duty Operating Speed	1464 RPM

The pump curves with the respective operational points are shown in the below figures:




Figure 4-7: Phase 1 Pump Curve with Duty Point 1




Figure 4-8: Phase 1 Pump Curve with Duty Point 2




Figure 4-9: Phase 2 Pump Curve with Duty Point 3

4.2.3 Pipework Optimisation

The selection of pipe sizes in the pumping station is done to ensure the pump station is effectively and efficiently able to convey sewage throughout the required flow ranges. The suction and delivery pipework sizes are selected to convey the current and ultimate flow rates between 125 l/s and 400 l/s.

Incoming sewage into the wet well has been screened and the remaining larger solids settled out in the grit settling channels, thus only organic material is expected in the wet well. The minimum recommended suction pipe velocity for sewage with organic matter is 0.6 m/s, with the maximum being 1.5 m/s. The maximum recommended velocity in the inlet bell of the suction pipework is 1 m/s. The maximum recommended velocity in delivery pipework is 2.5 m/s.

Table 4-6: Grit channel design values

Description	Pipe Diameter	Minimum Flow Velocity	Maximum Flow Velocity
Suction Bell	500 mm	0.61 m/s	1.02 m/s
Suction Pipework	450 mm	0.75 m/s	1.26 m/s
Delivery Pipework	350 mm	1.24 m/s	1.39 m/s
Delivery Manifold 1	350 mm	1.24 m/s	1.39 m/s
Delivery Manifold 2	450 mm	0.75 m/s	1.69 m/s
Delivery Manifold 3	500 mm	0.61 m/s	2.04 m/s

4.2.4 Pump Station Design

The pump station building design requires consideration of several factors – these have been incorporated in the design of the pump station:

- Suction and discharge mechanical arrangements
- Local start/stop and pressure sensors for each pump
- Sufficient space surrounding pumps for operators to move and work
- Valve handles at easy-to-operate heights
- Trenches sloping towards the sump to drain and spills or excess water
- Sump pump to return water to collection sump and be pumped
- Safety shower for operators to use if necessary and provide washing area
- Overhead crane for maintenance and replacement of pumps and mechanical equipment
- Flow meter at sufficient distances from upstream/downstream fittings for accurate readings
- Ablution facility (toilet, basin, shower), Control room, MCC room, LV/MV room, Transformer room, Generator room
- Control room to be separate from the pump well to reduce noise for operators, however still in sight for operators to see if there are issues with pumps – can also have remote control of the pumps from the control room
- Emergency access – 2 per level at a minimum – doors opening outward for emergencies
- Lighting & ventilation – as much natural light as possible to reduce the electrical load for air conditioning
- Vehicle access into the pump area for the loading & offloading of equipment directly with the overhead crane.
- Over-pumping connection to rising main for bypass of the pump station.

The pump station was designed with the space allowance for three (3) pumps to be installed initially to meet the initial requirements; as well as allow sufficient space to install 1 additional pump in the future to meet the final demand of 400 l/s as per the (GMSMP). This configuration will ensure that there is always standby availability for the pumps if any of the pumps have failed or need maintenance.

4.2.5 Control Philosophy

(a) Pumps

The pumps will be operated with VSDs to control the speed at which the pumps operate to meet a specific flow requirement in line with the start signal received from the wet well. The number of pumps operating is dependent on the level reached in the wet well. One pump will operate with flows up to 125 l/s, with an assist pump operating in parallel will operate with flows between 125 l/s and 238 l/s. The pumps will operate at a set speed dependent on the pumping configuration to ensure the required flow rate is met. The pumps will be rotated as to which of them is running so that wear and tear are evenly distributed, and maintenance can be properly planned and carried out (avoidance of one pump accumulating hours and the remaining not operating).

(b) Sumps

An ultrasonic level sensor will be placed in the collection wet well, with a high-level and low-level float installed in each separate extraction wet well. These sensors and switches will control the start of the pumps. The suction pipework for the pumps has been designed in such a way that each wet well can be emptied by 2 different pumps. Similar to the pumps, the wet wells will be able to be isolated and any combination of the wet wells used so that regular maintenance can be performed. In the event of a failure, the operational wet wells can be utilized while the faulty one is out of service.

(c) Pipework

Isolating valves will be placed on each of the suction pipes from the wet wells, as well as each of the pumps to determine which wet wells and pumps are operational at any time. There is also an isolation valve between the two to allow for complete switching or separation between sumps and pump sets.

Figure 4-10 below gives a layout of the sumps, pumps, and interconnecting pipework in the pump station. The blue pipelines indicate suction pipework, with blue valves on the sump pipes and orange valves on the pump suction

lines. The green pipelines indicate discharge pipework from the pumps with yellow valves on the discharge pipework; the valves interconnecting the pump suction pipes between the wet wells are shown in green.




Figure 4-10: Pump and Pipework layout

(d) Electronic metering

A single flow meter is located adjacent to the pump station that reads the collective flow from the pump station to the discharge point. The readings from this meter will be compared with the meters located at the head of the inlet works and in between to ensure all flows are accounted for.

4.2.6 Structures

The design of the structures is based on the guidelines and standards set out below.

(a) Guidelines

- Pipework in the control room building will be installed above the lower terrace level.
- The control room building has been sized to allow a minimum free passage for operational activities, cleaning and maintenance of equipment.
- The building will be a reinforced concrete frame structure complete with brick infill panels. The concrete columns will be founded on reinforced concrete pad footings, with the brick infill panels founded on reinforced concrete strip footings.
- All floors are to be 150mm thick reinforced concrete floors, with integrated plinths.
- Apron slabs around the building to be 100mm thick by 1,000 mm wide concrete slabs sloping away from the building.
- The roof structure connects to the top ringbeam. The pitched roof will consist of dual-pitch steel trusses, bracing and steel purlins with 0.53mm thick IBR sheeting placed on top.
- No allowance has been made for ceilings, insulation (thermal or sound), or solar panels.
- All doors will be double-leaf steel doors with a locking mechanism.

The following standards were used in the design of buildings and chambers:

- Construction of all buildings to conform to the requirements stipulated in SANS 10400:2010: The application of the National Building Regulations.

- The structural systems of all the buildings are designed to resist the permanent and superimposed loads specified in SANS 10160:2011: Basis of structural design and actions for buildings and industrial structures.
- All hot-rolled structural steelwork shall conform to the requirements of SANS 10162-1:2011: Part 1: The Limit-states Design of Hot-rolled Structural Steelwork.
- All cold-formed steel work shall conform to the requirements of SANS 10162-2:2011 Part 2: Cold-formed steel structures.
- All concrete foundations and other concrete elements conform to SANS 10100-1:2000: The Structural use of Concrete Part 1: Design.
- All brick walls shall be constructed to SANS 10164:1980 Part 1: The Structural use of Masonry Part 1: Unreinforced Masonry walling.

(b) Structural Materials

1. Concrete

The sumps (wet wells) will be constructed using reinforced concrete.

Concrete elements were designed to have the following minimum 28-day compressive strengths:

- Blinding: 15MPa
- Water retaining structures: 25MPa watertight concrete to BS8007, complete with an approved waterproofing admixture (such as Penetron),
- All other concrete: 25MPa

2. Reinforcement

Concrete elements are detailed with the following rebar sizes (complying with SABS 920):

- Mild steel (250MPa): R8, R10 and R12
- High yield steel (450MPa): Y10, Y12, Y16, Y20 and Y25

For corrosion protection of reinforcement, liquid retaining structures are specified to have a minimum concrete cover of 50mm and be cast complete with Penetron waterproofing admixture (or equivalent).

Concrete cast directly against soil, the cover will be 75mm.

3. Structural Steel

All steelwork located within the inside of liquid retaining structures is specified as stainless steel to avoid corrosion damage. External steelwork is specified as hot-dip galvanised. The structural steel grade is to be S355JR, steel plate grade to be 300WA and cold-formed steel to be commercial quality.

4.3 Electrical Load Requirements

4.3.1 Background

As discussed in detail in other sections of this report, the upgrading/modifications to the existing Thembaletu Pump Station No.6 will be done in phases.

The first stage will increase the capacity from the current 60 ℓ/s to 238 ℓ/s. This will require the replacement of the existing pumps and associated 75kW motors with new pump sets with the new pump sets and motor rated 132kW (PF=0.86). The motors will operate on one(1) duty and one(1) assist. This means that under peak flow conditions, a maximum of two (2) 132kW motors (two pumps in parallel) could be in operation at the same time.

The second stage of the upgrade will increase the capacity from 238 l/s to 400 l/s. This will require an additional two (2) new pumps and motors. The pump sets will operate two (2) duty, one (1) assist, and one (1) standby. This means that a total of four (4) motors will be installed and in peak flow conditions, a maximum of 3x 132kW motors could be in operation.

The expected load requirements for the different stages, which form the basis for the electrical equipment design and specifications, are calculated and summarised in the paragraphs below.

4.3.2 Phase 1 (Capacity: 238 l/s)

Table 4-7 below provides a summary of the expected maximum electrical demand associated with this phase of the project.

Table 4-7: Electrical Load Summary (Capacity 180l/s)

Description	Comment	Duty	Assist	Stand-by	Rating (kW)	Total Power (kW)	Power Factor	Total Power (kVA)
Inlet Works: Screens	2x Existing Huber mechanical screens can be re-used	1	0	1	1.5	1.5	0.85	1.75
Inlet Works: Conveyors	2x Existing conveyors can be re-used	1	0	1	1.5	1.5	0.85	1.75
Sewerage Pumps	3x New Pumps & Motors	1	1	0	132	264	0.86	307
Small Power & Lighting	Building & Security Lights	1	0	0	1.5	1.5	1.0	1.5
TOTAL (Expected Maximum Demand)						136.5		312

The maximum expected electrical demand for this stage of the pump station capacity upgrade is calculated to be **312 kVA**.

4.3.3 Phase 2 (Capacity: 400 l/s)

Table 4-8 below provides a summary of the expected maximum electrical demand associated with the second (final) phase of the project.

Table 4-8: Electrical Load Summary (Capacity 400l/s)

Description	Comment	Duty	Assist	Std/by	Rating (kW)	Total Power (kW)	Power Factor	Total Power (kVA)
Inlet Works: Screens	2x Existing Huber mechanical screens can be re-used	1	0	1	1.5	1.5	0.85	1.75
Inlet Works: Screens	2x New mechanical screens to be added	1	0	1	1.5	1.5	0.85	1.75

Inlet Works: Conveyors	2x Existing conveyors can be re-used	1	0	1	1.5	1.5	0.85	1.75
Inlet Works: Conveyors	2x New mechanical conveyors to be added	1	0	1	1.5	1.5	0.85	1.75
Sewerage Pumps	4x New Pumps & Motors	2	1	1	132	396	0.86	460.5
Small Power & Lighting	Building & Security Lights	1	0	0	1.5	1.5	1.0	1.5
						403.5		469

The maximum expected electrical demand for this stage of the pump station upgrade is calculated to be **469 kVA**.

4.4 Proposed Equipment

4.4.1 Medium Voltage Reticulation

Any upgrading/modifications to the existing bulk MV electrical supply to the Thembaletu Pump Station No.6 are excluded from the scope of work for this project and will be handled by the George Municipality directly if required. Although currently only being a radial (single feed) supply, not guaranteeing any redundancy, the existing medium voltage supply capacity is sufficient to cater for the maximum planned (future) load requirements. It is recommended that the spare 11kV feeder on the existing 3-way RMU be used to bring in an alternative supply to the pump station, in order to provide a redundant ring feed supply, thereby providing a more reliable source of bulk supply.

4.4.2 Equipment Room Layouts

It is assumed that all existing equipment rooms are big enough to accommodate any future equipment requirements. This can, however, be confirmed once actual equipment sizes are provided by the various suppliers. No electrical equipment room modifications and currently anticipated and no expansions are allowed for as part of this project.

4.4.3 Medium Voltage Switchgear

The existing 11kV RMU (3-way) and associated Metering Unit, as discussed in detail in Section 3.4.3 of this report, is correctly rated to accommodate the maximum expected load for the future pump station requirements. It is important to note that there is currently only one (1) transformer feeder, supplying the existing 315kVA transformer. Seeing that a second power transformer will be installed in the future, an additional transformer feeder will have to be added to the existing gas-insulated switchgear. This panel should have the same rating, as well as protection, metering and control functionality as the existing transformer feeder panel.

Schneider Electric did indicate that the existing RM6 type, 17.5kV gas-insulated switchgear currently used can be extended on the right-hand side of the panel, by adding an additional transformer feeder circuit breaker panel. This addition can be done on-site.

4.4.4 Power Transformers

4.3The existing 315kVA rated power transformer will not be sufficient to accommodate the expected load for the Phase 1 (238 kVA) upgrade of the pump station. Based on the load calculations, a new 630kVA-rated transformer will be required to supply the pump station loads for phase 1.

Furthermore, it should be noted that the installation of only one (1) transformer will result in a non-redundant system with a single point of failure. It is therefore recommended that two (2) 630kVA power transformers be

installed to supply the total pump station load. Although each transformer will under normal operating conditions only supply 50% of the load, the dual installation will ensure that any one of the transformers can supply the total pump station load under a single contingency (N-1) condition.

The existing transformer room is big enough to house two (2) 630kVA transformers, provided that the existing 315kVA transformer be de-commissioned and removed from the site to make space for one of the new 630kVA transformers. Furthermore, it should be noted that an existing transformer is an oil-filled unit, which does pose a fire risk, especially when installed in a dedicated room (as is the current case). With open cable trenches, protruding to the other rooms, the risk of burning transformer oil being spread quickly throughout the entire building is a major fire hazard. For this reason, it is recommended that the new transformers be of the dry-type (vacuum pressure-impregnated cast-resin).

Although approximately 30% more expensive than the oil-filled units, VPI transformers utilise high-temperature (Class H-rated) insulation for the insulating materials. The windings are dried out and vacuum/pressure impregnated using silicone or polyester-based varnish before being baked to cure the varnish. The design and construction of the windings together with the VPI treatment of the winding ensure that it is electrically sound as well as mechanically strong. Although first produced as supply transformers for high-rise buildings, it became evident that this design is perfect for flameproof and high protection class non-flameproof enclosures where their sturdy electrical and mechanical construction allows them to handle harsh environmental and electrical requirements e.g. the repeated D.O.L. starting of large motors, frequent short circuits and excessive operating temperatures.

An image of a typical dry-type transformer (and enclosure) is shown in Figure 4-11 below.



Figure 4-11: Typical Dry-type Transformer (credit: Toshiba)

4.4.5 Medium Voltage Power Cables

Although it could not physically be confirmed on site, it can be seen from the existing single line diagram (Figure 3-10), that an 11kV, 25mm², Copper power cable is used between the MV Metering Unit and the existing 315kVA main power transformer. Although this cable is load-rated to carry 115A, 2.2MVA @11kV, when installed in ducts/trenches, it should be noted that this cable is fault-rated to withstand a 10kA symmetrical short-circuit fault for only 200ms, before damaging the cable. In lieu of the fact that this cable is supplied from a circuit breaker and protection relay and not a fast-acting fuse, we are of the opinion that this cable is not sufficiently protected against fault conditions.

Assuming a maximum symmetrical short-circuit fault level of 10kA (@11kV) at this pump station, we would recommend that a cable be selected to withstand this fault rating for at least 500ms, in order to allow sufficient time for the protection element to detect the fault and the circuit breaker to clear the fault, without causing any thermal damage to the cable. For this reason, it is recommended that the MV cables between the 11kV RMU and the transformer primary windings be rated as follows:

- Rated Voltage: 6.35/11kV
- Conductor Type: Copper
- Insulation Medium: XLPE
- Conductor Size: 50mm²
- Number of Cores/Cable: Three core
- Armoring: None

4.4.6 Low Voltage Switchgear

(a) Main Incoming Section

Based on the assumption that two (2) 630kVA power transformers will be used to provide a redundant supply to the total LV load, and a single standby diesel generator incorporated to provide backup power to the total facility, it is recommended that a five (5) breaker main incoming low voltage section (see the typical layout in the image below) be considered. This arrangement will consist of the following:

- Panel 1: Main LV Incomer - Transformer No.1 (1250A)
- Panel 2: LV Feeder 1 - MCC No.1 (800A)
- Panel 3: Standby LV Incomer - Generator No.1 (1250A)
- Panel 4: LV Feeder 2 - MCC No.2 (800A)
- Panel 5: Main LV Incomer - Transformer No.2 (1250A)



Figure 4-12: Proposed Main LV Incoming Section

(b) All mains fail detection, automatic change-over functionality and control between the different sources will be incorporated in dedicated control devices, that will be housed on the panels (as indicated in the example above). Based on the 1.5 MVA rating of the standby generator, it is recommended that the busbars of this Main LV Incoming Section be rated 2000A, 31.5kA (1s). Motor Control Centres

Based on the new pumps and associated equipment to be installed as part of the upgrade for each of the two (2) sumps, it is recommended that a dedicated new MCC be installed for each sump's equipment. A typical example of such an MCC arrangement and size is shown in the figure below.




Figure 4-13: Typical MCC Arrangement (credit: Tricom Africa)

Each MCC layout will include at least the following functional units:

MCC 1 (Sump 1)

1. Main incoming section (1000A)
2. Local distribution section
3. Control section: mechanical screen 1 (1.5kW)
4. Control section: screw conveyor 1 (1.5kW)
5. Control section: sewage pump 1 (132kW)
6. Control section: sewage pump 2 (132kW)
7. Local control section (including RTU/controller)
8. Wireways & distribution terminals

MCC 2 (Sump 2)

1. Main incoming section (1000A)
2. Local distribution section
3. Control section: mechanical screen 2 (1.5kW)
4. Control section: screw conveyor 2 (1.5kW)
5. Control section: sewage pump 3 (132kW)
6. Control section: sewage pump 4 (132kW)
7. Local control section (including RTU/controller)
8. Wireways & distribution terminals

Furthermore, it is recommended that the screw conveyor and mechanical screens be equipped with WEG CFW-11 variable frequency drives, whilst the six (6) sewage pumps are started via WEG variable speed drives with the correct ratings.

All power and control cables will be bottom entry via cable trenches and neatly managed between the MCC and the motors by means of heavy-duty cable racks, mounted against the walls.

4.4.7 Standby Diesel Generator

The current generator on site, sized at 403 kVA (442kVA standby) according to the nameplate values, is not of sufficient size to power the new motors after the upgrade required at phase one. The minimum generator requirements are

Capacity for one (1) motor running:	180.5 kVA (1x 132kW, pf=0.86, eff=0.85)
Capacity for one (1) motor starting (VSD):	<u>361 kVA (2x full load current)</u>
Total generator capacity required:	541.5 kVA
Generator capacity (prime rated):	600 kVA
Generator capacity (emergency-short time):	1100 kVA

The following design is considered for the final phase design (400 L/s).

The RFQ document, received from the George Municipality, for this project calls for the installation of a 1500 kVA (1200 kW prime-rated) standby diesel generator to provide backup power to the entire pump station facility. Based on the final load calculations (refer to Section 4.3), SMEC is of the opinion that this rating is too high for the application. Oversizing a standby generator for any specific installation leads to a number of disadvantages, such as a larger footprint, higher fuel consumption, thicker power cables required, and higher capacity switchgear ratings, to mention but a few. The biggest concern, however, is the fact that if a diesel engine is operated at lower than 30% of its design capacity, it leads to carbonisation of its combustion chambers, hence requiring much more maintenance or additional load banks to be installed to increase the loading on the machine for short durations to avoid carbonisation.

Furthermore, keeping in mind that the upgrading of Thembaletu Sewage Pump Station No.6 will be done in phases, the initial stage (capacity of 238l/s) will require a maximum of only 2x 132kW motor to be operated under peak flow conditions. As detailed in Section 4.3.2 a maximum demand of only 312 kVA is estimated for this phase of the project. The 1500 kVA diesel generator will be able to support this load.

Based on the calculations detailed in Section 4.3.3 of this report, for the final stage (capacity of 400l/s) a maximum demand of 469 kVA is estimated with 3x 132 kW motors being required to be in operation at the same time. For this ultimate scenario, it would mean that the 1500 kVA diesel generator will only be operated at 31% of its design capacity. (This assumption is based on full load running conditions for the motors and does not take motor starting conditions into account).

SMEC would like to recommend that an **800 kVA generator (640 kW prime rated)** be considered instead, as this would be a much better-suited rating for this specific application. When considering the worst-case scenario for the 400l/s stage, the following high-level calculation can be done to confirm the generator requirements:

Capacity for one (1) motor starting (DOL):	<u>1084kVA (6x full load current)</u>
Total generator capacity required:	1446 kVA
Generator capacity (prime rated):	800 kVA
Generator capacity (emergency-short time):	1600 kVA
Capacity for two (2) motors running:	362 kVA (2x 132kW, pf=0.86, eff=0.85)

This means that an 800 kVA generator will have sufficient capacity to start a fourth motor when the other three motors are already in operation. A sequential starting simulation was done to confirm this calculation and has been

included in Annexure A for reference purposes. An important factor to keep in mind during the detailed design phase of the project will be to ensure that more than one motor is not started at the same time. This could easily be incorporated into the MCC design by means of “time delay to start” relays, with different time settings. This will ensure the sequential starting of the motors whenever a power interruption has been experienced.

The expected loading on the 800 kVA unit for the different stages is expected to be:

Stage 1 (238l/s):	261/800 kVA = 39%
Stage 2 (400l/s):	520/800 kVA = 59%

These values (even for Stage 1 requirements) are higher than the minimum 30% operating capacity of the generator.

Typical dimensions for an 800 kVA generator set are indicated in the figure below. As can be seen from this image, this unit will definitely be accommodated in the existing generator room.




Figure 4-14: Typical 800kVA Generator General Arrangement (credit: Himoina)

Typical fuel consumption values for the 800kVA (640kW) standby diesel generator are specified as follows:

- Fuel consumption 100% prime rated power: 156.64 l/h
- Fuel consumption 70% prime rated power: 112.28 l/h
- Fuel consumption 50% prime rated power: 84.09 l/h

4.4.8 Telemetry & SCADA

The telemetry and SCADA for George Municipality applications are currently done under a separate SLA by Spectrum Communications. The existing Spectrum Teleflex 5 RTU that acts as both controller and Telemetry RTU would be expandable to allow for all the additional equipment, associated with the new motor control applications. It is recommended the same type of equipment be used as part of the upgrade project for the fact that the replacement parts are on hand in George with no lead time on replacement, repair, or servicing of this equipment.

Seeing that this portion of the work will be sub-contracted to Spectrum, a budgetary figure has been allowed for a hardware upgrade, control algorithm alteration/rewrite SCADA and commissioning

4.4.9 Earthing and Bonding

For the proposed new pump station building a network of inter-connected earth electrodes (consisting of earth rods and conductors) will be installed around the building to ensure an overall resistance to earth of $1\ \Omega$ or less providing an effective earth mat. The minimum requirements for the earth rods and electrodes are provided in the tables below. The number of earth rods to be installed around the building will be calculated during the detailed design stage based on the soil resistivity measurements taken on-site as per the position of the new building to be constructed.

Earth Electrode Rods:

Table 4-9: Standard for Earth Rod Dimensions

Material	High Tensile Steel, Copper Coated
Size	Ø 16 mm
Length	1800 mm

Earth Electrode Conductors:

Table 4-10: Standard for Earth Electrode Dimensions

Material	Bare Copper (Stranded)	Bare Copper (Solid)	Copper-Clad Steel (Stranded)
Size	70 mm ²	Ø 10 mm	95 mm ²

Earth electrodes shall be installed as deep as possible, but not less than 900mm below the natural ground level. Deep-buried electrodes exhibit less steep voltage gradients at the soil surface during times of discharge and reduce the risk of mechanical damage or theft of the earth electrode. The network of underground earth electrodes and conductors around the building will be bonded onto a 50mm x 6mm bare copper bar (main earth bar), installed inside the pump station building equipment room by means of a 120mm² bare copper conductor.

Each of the other equipment rooms within the building will also be equipped with a 50mm x 6mm bare copper earth bar (safety earth bar). These safety earth bars within the rooms will be connected to the building's main earth bar by means of 70mm² PVC-covered copper conductors to ensure the integrity of the equipotential platform created within the building.

All accessible conductors, portions of the electrical plant, or equipment which do not form part of an electrical circuit, but have the possibility of accidentally becoming energised during normal or fault conditions, shall be bonded to the nearest safety earth bar.

4.4.10 Building Small Power & Lighting

An allowance has been made in the budget estimate to provide some basic small power and lighting requirements for the additional offices/store rooms that will be constructed as part of the upgrade project. All new sub-distribution boards, light switches, conduits and socket outlets will be recessed in the walls (as per the current design).

All luminaires specified for the new and/or existing rooms will be energy-efficient LED type and will also be vaporproof.

4.5 Rising Main

The planning and design of the water transfer infrastructure are based on the following principles:

- The provision and installation of isolating, air, non-return and scour valves will be limited to essential locations as required for the efficient functioning of the system;
- Pipelines are to be routed such that it has minimal interference with other structures, parallel to the existing pipe;
- Pipelines to follow services corridor and existing pipe route crossing the Schaapkop River over the existing steel pipe bridge;
- All valve assemblies are to be housed in valve chambers;
- Pipes are to be placed underground except over the existing pipe bridge.

4.5.1 Horizontal Alignment

The rising main route will follow the existing 250mm diameter pipeline with a provisional parallel offset of 2.5m.

Bearing-type anchor blocks will be constructed at each horizontal bend where the flow changes direction. The purpose of this block is to support the bend, reduce movement of the pipeline and stop the pipe joints from being pulled apart causing a joint failure. The bearing-type anchor block is part of the design to safely transit the unbalanced thrust forces to the undisturbed soil.

The horizontal alignment has a point of intersection (PI) at each location where there is a change in the flow direction. During the Concept and Viability report, it was attempted to use locally manufactured PVC pipe bends, including an 11.25°, 22.5°, and 45°. 90° bends will not be used as far as possible.

The pipe manufacturer allows for a 1° deflection over one pipe length in each joint to absorb minor changes in directions.

4.5.2 Vertical Profile

The vertical profile is mainly affected by the ground levels along the path of the horizontal alignment, which follows the route and the profile of the existing rising main.

In the vertical design of the pipe, provision has been made for air valves at all high points and significant changes in grade along the entire route, including at the pumps, the control chamber and the crossing of the Schaapkop river bridge. Provision for scouring valves at all low points and between valved sections of the pipeline was made.

The scour valve will ensure the pipe can be emptied to remove all the sediment trapped at the low point, but also allow the pipe to drain in a reasonable time in case of maintenance.

As it is an environmentally sensitive area, scouring into waterways will not be allowed. Perrot Couplings are allowed onto which a piped suction system from Water Spillage Truck (Honey Sucker) can be connected to take up the water volume to prevent discharging into the watercourse.

4.5.3 Pipeline Material Selection

(a) Ductile Iron Pipes

A portion of the rising main will cross the Schaapkop Pipe Bridge and will be exposed above ground. The existing 250mm diameter rising main crossing the Schaapkop pipe bridge is Ductile Iron, and has been selected to be used for the new 400mm diameter as well.




Figure 4-15: Pipe fixture on bridge structure

Ductile iron pipes are as robust as steel pipes and are slightly less prone to corrosion and cathodic reaction. They are also normally epoxy lined and coated to improve corrosion protection.

Ductile Iron pipes normally have spigot and socket joints which simplifies installation. Due to the Spigot and Socket jointing system, the installation of valves and other specials require special CI attention and CI fittings.

The ductile iron pipes are also normally supplied in lengths between 6- to 12m which also means that the pipes become heavy at large diameters. This will require specialist lifting equipment for installing the pipes.

(b) PVC-U Pipes

This pipe has been selected due to their better hydraulic performance and better mechanical performance for the 400 mm diameter pipe. Stainless-Steel, epoxy-coated fittings will be used for special bends where required

- PVC-O pipes have a higher resistance to impact.
- PVC-O pipes offer lower celerity than steel piping systems (four times less than ductile iron pipes), which means lower transient pressures during sudden variations in water volume and pressure. This reduces and almost eliminates the possibility of breakage during opening and closing in the water network and when pumping gets under way.
- Increased hydraulic capacity –The internal surface is extremely smooth, reducing head loss and making reducing the potential for deposit.

A complementary range of valves and fittings is available. OPVC pressure bends are manufactured to PN16 working pressures.. The range of bends is available in 11.25°, 22.5°, 45° and 90°. They are also lighter in weight than the metal pipes which will lend itself to easier construction in the areas where space could be restricted.

“Viking Johnson” or similar flexible couplings are used to connect these fittings to plain-ended pipes. The “Viking Johnson” joint is a mechanical joint in which a rubber seal is compressed against the pipe spigots by tightening the bolts on the joint. The correct “barrel” length of the “Viking Johnson” joint must be used to allow for expansion and contraction of the PVC pipe or any possible movement after installation of the pipeline.

4.5.4 Water Hammer Analysis

(a) Introduction

A water hammer analysis was conducted of the Thembaletu transmission system. The objective of the analysis was to identify and optimise water hammer mitigation measures.

The Thembaletu transmission system consist of a pump station with an approximately 680 m long force main that discharges into a manhole. The system was modelled with three steady flow scenarios:

1. Design Condition, low flow – where the design flow equals 125 l/s and sewage being pumped via one force main.
2. Design Condition, high flow – for this scenario the design flow equals 238 l/s while pumping via one force main.
3. Ultimate Condition – a design flow totalling 400 l/s and sewage being pumped via a second force main. The second force main will be horizontally aligned parallel to the Design Condition's force main route with a 5 m distance between the two pipelines. Furthermore, the two force mains' pipe diameters and materials are identical.

(b) Assumptions

The following assumptions were made during the model construction to ensure that the desired design flows are attained for the two different steady state conditions.

(i) Pump Station Characteristics

Refer to Figure 4-16 below that reflects the assumed pipework diameters. All pipework was assumed to be manufactured of stainless steel. The wave celerities of the different pipework diameters are provided in Table 4-11 below.

Table 4-11: Pump Station Pipe Work Hydraulic Data

Outside Diameter (mm)	Wall Thickness (mm)	Material	Wave Celerity (m/s)	Design Condition – Flow Velocity (m/s)	Ultimate Condition – Flow Velocity (m/s)
273.1	3.4	Stainless Steel	1,109.9	1.61	2.42
323.8	4.0	Stainless Steel	1,108.0	1.15	1.72
355.6	4.0	Stainless Steel	1,084.8	1.89	2.85
457.2	4.2	Stainless Steel	1,032.4	1.13	2.57

The pump curves were obtained from a pump manufacturer and is reflected in Figure 4-17 below. The duty point of one pump is 133.3 l/s at 65 m pumping head. Three duty pumps and one standby pump will be installed for the ultimate condition. It is assumed that for the low flow design condition (125 l/s), one (1) duty pump will operate at 95 % of its rated speed namely, 1,418.9 r.p.m. For the high flow design condition (238 l/s), two duty pumps will operate at 98 % of its rated speed – 1,460.7 r.p.m.

The pumps' installed motor power rating will be 132 kW and the mass moment of inertia of the pumps were estimated using an empirical equation – 4.53 kg.m². The pump specific speed is calculated as 23.8u with the following equation: $n_s = \frac{N\sqrt{Q}}{H^{0.75}}$ where, n_s is specific speed, Q is discharge rate (m³/s) and H is the pumping head (m).




Figure 4-16: Isometric View of the Pump Station with Pipe Diameters

Performance curve




Customer item no.:
 Communication dated: 19/04/2023
 Doc. no.: Quick quote
 Quantity: 1

Number: ES 8002359938
 Item no.: 100
 Date: 19/04/2023
 Page: 3 / 8

Sewatec K 150-503G 3EN 315M 04

Version no.: 1



Curve data

Speed of rotation	1492 rpm	Efficiency	75.1 %
Fluid density	998 kg/m ³	Power absorbed	112.67 kW
Viscosity	1.00 mm ² /s	NPSH 3%	5.18 m
Flow rate	133.000 l/s	Curve number	K43630/0
Requested flow rate	133.000 l/s	Effective impeller diameter	482.0 mm
Total developed head	65.00 m	Acceptance standard	Tolerances to ISO 9906
Requested developed head	65.00 m		Class 3B; below 10 kW
			acc. to paragraph 4.4.2

Figure 4-17: Pump Characteristic Curves

(ii) Force Main Characteristics

The following force main data was used for both the Design Condition and the Ultimate Condition:

Table 4-12: Force Main Hydraulic Data

Outer Diameter (mm)	Wall Thickness (mm)	Material	Wave Celerity (m/s)	Length (m)	Description	Design Condition – Flow Velocity (m/s)	Ultimate Condition – Flow Velocity (m/s)
400	18.4	UPVC, Class 12	430.9	636.6	Buried pipe	1.73	1.97
429	8.1	Ductile iron, Class K9	1,166.1	36.9	Pipe bridge	1.34	1.52

The pipes' hydraulic friction losses were calculated with the Darcy Weisbach equation. The absolute roughness of the pipes was assumed as 0.03 mm.

(c) Transient Events

Six transient flow scenarios were identified and were modelled using Bentley's Hammer software. The transient flows consisted of pump start and pump trip. The scenarios that were modelled include:

1. Scenario 1: Design Condition, Low Flow.
 - 1.1. Scenario 1.1: Pump Trip.
 - 1.2. Scenario 1.2: Pump Start.
2. Scenario 1: Design Condition, High Flow.
 - 2.1. Scenario 2.1: Pump Trip.
 - 2.2. Scenario 2.2: Pump Start.
3. Scenario 2: Ultimate Condition.
 - 3.1. Scenario 3.1: Pump Trip.
 - 3.2. Scenario 3.2: Pump Start.

For Scenarios 1.1, 2.1 and 3.1 (pump trip), all the pumps were modelled to simultaneous stop and run down to a stationary condition as a function of the pump impeller, coupling and motor rotor's mass moment of inertia.

Scenarios 1.2, 2.2 and 3.2 consists of starting the duty pumps and gradually increasing its speed from 0 to 95 % over a period of 7.9 seconds, 0 % to 98 % over a period of 10.8 seconds and 0 % to 100 % over a period of 12 seconds respectively.

(d) Results

The water hammer results are represented as several plots reflected in the images from Figure 4-18 to Figure 4-40.

(i) Scenario 1.1, Low Flow Design Condition, Trip




Figure 4-18: Scenario 1.1 – Maximum Water Hammer Pressure Values




Figure 4-19: Scenario 1.1 – Minimum Water Hammer Pressure Values



Figure 4-20: Scenario 1.1 – Maximum and Minimum Water Hammer Grade Line Envelopes




Figure 4-21: Scenario 1.1 – Maximum and Minimum Water Hammer Pressures Along Pipeline




Figure 4-22: Scenario 1.1 – Air Volume Inside a Strategically Positioned Air Valve




Figure 4-23: Scenario 1.1 – Pressure and Flow Directly Downstream of the Pump Station

(ii) Scenario 1.2, Low Flow, Design Condition, Start




Figure 4-24: Scenario 1.2 – Maximum Water Hammer Pressure Values




Figure 4-25: Scenario 1.2 – Minimum Water Hammer Pressure Values



Figure 4-26: Scenario 1.2 – Maximum and Minimum Water Hammer Grade Line Envelopes




Figure 4-27: Scenario 1.2 – Maximum and Minimum Water Hammer Pressures Along Pipeline




Figure 4-28: Scenario 1.2 – Pressure and Flow Directly Downstream of the Pump Station

(iii) Scenario 2.1, High Flow, Design Condition, Trip




Figure 4-29: Scenario 2.1 – Maximum Water Hammer Pressure Values




Figure 4-30: Scenario 2.1 – Minimum Water Hammer Pressure Values




Figure 4-31: Scenario 2.1 – Maximum and Minimum Water Hammer Grade Line Envelopes Along the New Pipeline




Figure 4-32: Scenario 2.1 – Maximum and Minimum Water Hammer Pressures Along the New Pipeline




Figure 4-33: Scenario 2.1 – Maximum and Minimum Water Hammer Pressures Along the Future Pipeline




Figure 4-34: Scenario 2.1 – Air Volume Inside a Strategically Positioned Air Valve Along the New Pipeline




Figure 4-35: Scenario 2.1 – Pressure and Flow Directly Downstream of the Pump Station

(iv) Scenario 2.2, High Flow, Design Condition, Start




Figure 4-36: Scenario 2.2 – Maximum Water Hammer Pressure Values




Figure 4-37: Scenario 2.2 – Minimum Water Hammer Pressure Values



Figure 4-38: Scenario 2.2 - Maximum and Minimum Water Hammer Grade Line Envelopes Along the New Pipeline




Figure 4-39: Scenario 2.2 – Maximum and Minimum Water Hammer Pressures Along the New Pipeline




Figure 4-40: Scenario 2.2 – Pressure and Flow Directly Downstream of the Pump Station

(v) Scenario 3.1, Ultimate Condition, Trip




Figure 4-41: Scenario 3.1 – Maximum Water Hammer Pressure Values




Figure 4-42: Scenario 3.1 – Minimum Water Hammer Pressure Values




Figure 4-43: Scenario 3.1 – Maximum and Minimum Water Hammer Grade Line Envelopes Along the New Pipeline




Figure 4-44: Scenario 3.1 – Maximum and Minimum Water Hammer Pressures Along the New Pipeline




Figure 4-45: Scenario 3.1 – Maximum and Minimum Water Hammer Grade Line Envelopes Along the Future Pipeline




Figure 4-46: Scenario 3.1 – Maximum and Minimum Water Hammer Pressures Along the Future Pipeline




Figure 4-47: Scenario 3.1 – Air Volume Inside a Strategically Positioned Air Valve Along the New Pipeline




Figure 4-48: Scenario 3.1 – Air Volume Inside a Strategically Positioned Air Valve Along the Future Pipeline




Figure 4-49: Scenario 3.1 – Pressure and Flow Directly Downstream of the Pump Station

(vi) Scenario 3.2, Ultimate Condition, Start




Figure 4-50: Scenario 3.2 – Maximum Water Hammer Pressure Values




Figure 4-51: Scenario 3.2 – Minimum Water Hammer Pressure Values



Figure 4-52: Scenario 3.2 - Maximum and Minimum Water Hammer Grade Line Envelopes Along the New Pipeline




Figure 4-53: Scenario 3.2 - Maximum and Minimum Water Hammer Pressures Along the New Pipeline



Figure 4-54: Scenario 3.2 – Maximum and Minimum Water Hammer Grade Line Envelopes Along the Future Pipeline




Figure 4-55: Scenario 3.2 – Maximum and Minimum Water Hammer Pressures Along the Future Pipeline




Figure 4-56: Scenario 3.2 – Pressure and Flow Directly Downstream of the Pump Station

(e) Conclusions

The system's maximum water hammer pressure will occur during a pump trip with the Ultimate Condition as the initial steady state condition. The maximum pressure will be 10 Bar at chainage 364 m (according to the drawings).

Furthermore, vapour conditions will occur when pumps trip for both the Design and Ultimate Condition. Vapour conditions will occur at chainage 601.8 m and elevation 156.2 m (according to the drawings). Vapour conditions are unacceptable because when vapour conditions develop, the water column 'breaks' and 'collapses' again when the water column reverses flow direction. This collapsing column results in cavitation and results in localised pressure spikes that could compromise the pipe's structural integrity.

(f) Recommendations

The following recommendations are made to alleviate maximum and minimum water hammer pressures:

1. For the Design Condition, two duty pumps must start simultaneously with a gradual increase in speed. The two pumps need to accelerate from 0 % speed to 90 % over a period of 10.8 s.
2. For the Ultimate Condition, three duty pumps must start simultaneously with a gradual increase in speed. The three pumps need to accelerate from 0 % speed to 100 % over a period of 12 s.
3. Both force mains require a strategically positioned air valves. The air valves need to be positioned at chainage 601.8 m with an elevation of 156.2 m. The air valves must be of a special type namely:
 - a. Sewage type.
 - b. Tripple acting type (incl. anti-slam orifice).
 - c. Inclusive of a mechanism (for instance a spring) to keep the valve closed under low pressure (1.27 Bar) conditions during steady flow conditions.
 - d. Intake orifice diameter size of at least 25 mm.
 - e. Anti-slam orifice diameter size of at least 5 mm.

4.6 Design Specifications

The following Standardised Specifications shall generally apply to the design and construction of the collection system and general civil works:

SANS 1200A	General
SANS 1200C	Site Clearance
SANS 1200D	Earthworks
SANS 1200DB	Earthworks (Pipe trenches)
SANS 1200DK	Gabions and Pitching
SANS 1200DM	Earthworks (Roads, Sub grade)
SANS 1200G	Concrete
SANS 1200H	Structural Steel
SANS 1200HC	Coorsion protection for Structural Steelwork
SANS 1200L	Medium-Pressure Pipelines
SANS 1200LB	Bedding (Pipes)
SANS 1200LC	Cable Ducts
SANS 1200LD	Sewers
SANS 1200LE	Stormwater Draingage
SANS 1200M	Roads
SANS 1200ME	Subbase
SANS 1200MF	Base
SANS 1200MJ	Segmented Paving
SANS 1200MK	Kerbing and Channeling

4.6.1 Pipework and fittings

The following specifications shall generally apply to pipes and fittings:

- SANS 719 : Electric welded carbon steel pipes for aqueous fluids – large bore for pipelines and fittings exceeding 150 mm in diameter
- SANS 1123 : Pipe flanges
- SANS 664 : Cast iron gate valves for waterworks
- BS5155 : Butterfly valves
- SANS 16422 : Pipes and joints made of oriented unplasticized polyvinyl chloride (PVC) for the conveyance of water under pressure.

The positions of air valves, scour valves, horizontal bends, vertical bends are indicated on the longitudinal sections. Details are indicated on separate plans in **Annexure A**

4.6.2 Associated Infrastructure

(a) Bulk earthworks and roads

1. Earthworks

The following design standards apply:

- South African Bureau of Standards (SANS)
- SANS 1200 for services (Water & sewer)
- TRH14 Guidelines for road construction materials
- TRH20 The structural design, construction and maintenance of unpaved roads

All platforms are to be free draining with no ponding. Surface drainage with open canals is the primary solution. Stormwater originating to be drained around and away from site

Subsurface drainage is the secondary solution. In areas where ponding cannot be eliminated, sub-surface drainage conduits are to be designed. Safety and ease of maintenance and operation are the main considerations.

2. Access Roads

The geometric design standards must be designed according to the TRH17 guidelines. The design standards for the roads are summarized in table 3 below.

Table 4-13: Summary of design standards for access roads

Description		Value
Width	Road width	5.0 m
Cross-fall	General cross-fall slope	2%
Surfacing	General surface (Base)	150mm G5 Base material compacted
	Grades above 14%	150mm Concrete surface with Mesh 193 reinforcement
	Sub-Base	• Grades above 14% - 200mm C4 stabilised material Compacted

The following design standards apply:

- South African Bureau of Standards (SANS)
- COLTO
- SANS 1200
- SATCC Code of Practice for the Design of Road Pavements
- SADC Roads and Bridge Design Standards and Specification;

- TRH4 - Structural Design of Flexible Pavements for Interurban and Rural Roads, COLTO;
- TRH14 Guidelines for road construction materials
- TRH20 The structural design, construction and maintenance of unpaved roads

1.1.1. Stormwater

The Road Drainage Manual published by the South African National Roads Agency is used in the design of all stormwater-related infrastructure.

(b) Thrust Blocks

The purpose of the thrust block is to support the bend and stop the pipe joints from being pulled apart causing a joint failure. The thrust block is part of the design to safely transit the unbalanced thrust forces to the undisturbed soil. As mentioned above, no thrust blocks will be designed for changes in the vertical profile due to changes in the direction being smaller than 10 degrees, but several thrust blocks are needed to support the pipe along with changes in the horizontal alignment of the new pipe.

The internal pressure of the pipe acts perpendicular to any plane with a force equal to the pressure, P , times the area of the pipe (using the internal pipe diameter). The thrust block design is based on the SANS 2001-DP2:2010 manual for medium-pressure pipelines.

The shape of the thrust block is designed as a trapezium with a height that is adequate to ensure the area required to withstand the thrust forces with a minimum thickness of 100mm around the pipe.

The concrete of the thrust blocks is Class 25/19 for all Bends and Tees.

4.6.3 Valves, Fittings and Specials

(a) Valve Chambers and Ancillary Equipment

The following design approach was followed for the various components:

- Reinforced brick and concrete valve chambers;
- Stainless-Steel of grade 316L pipework to SANS 719, Grade B – painted epoxy lined; high build polyurethane coated; and
- All valves and fittings shall be internally and externally coated with fusion-bonded epoxy.

(b) Scour Valves

The design of the rising main includes the provision of scour valves.

The scour assembly will be connected to the main pipe with an 500mm Scour T-Piece of stainless-steel flanged all ends.

Gate valves shall be of the RSV gate type, VOSA, Premier, or similar approved, double flanged with Ductile Iron bodies and stainless-steel trim and shall conform with all relevant sections of SANS 664 or BS 5163, specifications and subsequent amendments. Flanges shall be drilled to BS4504 or SANS 1123 for 16 bar working pressure as specified, and compatible with pipework flanges.

The gate shall be guided within the body of the valve to fit accurately onto the seat and to avoid possible buckling. Where extended spindles are required, they shall be suitably supported to prevent swaying and buckling and to guarantee the intended use of the valve. All gate valves shall be drop-tight when tested in accordance with the requirements of BS 5163.

All valves shall be capable of being operated manually with a maximum applied torque of 100Nm.




Figure 4-57: Scour assembly

The end piece will be fitted with a "Perrot" Coupling or similar approved. All other valves shall be provided with a cap top for use with a valve key.

(c) Air Valve

The design of the rising main includes the provision of air valves.

The air valve will be connected to the main pipe with an unequal 500mm T-Piece with a 300mm branch stainless-steel flanged fitting.




Figure 4-58: Airvalve assembly

In the chamber the following fittings will be accessible:

- Equal Tee-connection fitting
- Flanged Reducer (500 mm to 300 mm Reducer)
- Flanged Riser piece
- 150mm RSV Gate Valve
- 150mm Air Valve RGX
- 500 mm Flanged adaptor

Air release and vacuum break valves shall be double orifice with anti-shock orifice mechanism, of type "Vent-O-Mat Series RGX – Anti-Surge" or similar approved with flanged inlets and rated for a minimum of 16 bar working pressure as specified.

The valve shall have an integral surge alleviation mechanism which shall operate automatically to limit transient pressure rise or shock induced by closure due to high-velocity air discharge or the subsequent re-joining of separated water columns. The limitation of pressure rise must be achieved by deceleration of approaching water prior to valve closure.

The intake/discharge orifice area shall be equal to the nominal size of the valve. The inlet shall be fitted with an isolating valve with a vertical spindle, key operated from above.

(d) Non-Return Valves

Flanged multi-door check valve, Three piece design, multi-door, replaceable centre, lever arm and counterweight. Rapid closing times without slamming.

4.6.4 Control Assembly

A surge and flow control arrangement will be installed which will include Air relief valves, and surge anticipating valve arrangement, which is an off-line, hydraulically operated, diaphragm-actuated valves and flow control valve to arrange flow regime with the pipe to ensure design velocities are kept.

The surge anticipating valve, sensing line pressure, opens in response to the pressure drop associated with abrupt pump stoppage. The pre-opened valve dissipates the returning high-pressure wave, eliminating the surge. It smoothly closes drip tight as quickly as the relief feature allows while preventing a closing surge.




Figure 4-59: Control assembly section




Figure 4-60: Control assembly

4.6.5 Corrosion Protection

All the fittings and couplings will be 316L Stainless-Steel FBE coated, or two-pack epoxy coated galvanised mild steel, epoxy-coated ensuring protection against corrosion. For sizes 400mm, plain-ended fabricated bends, equal tees, scour tees, reducing tees, reducers, flanged adaptors, end caps and saddles are available. These fittings are suitably protected against corrosion.

All joints shall be Stainless-Steel flanged and drilled to SABS 1123:1977 Table 1600/3. All joints shall be protected by rapping with Denso S43R23 WRAP.

5 Operation and Maintenance

5.1 Operational and Maintenance Requirements

The operation and maintenance requirements of the proposed schemes will be similar to the requirements of the existing water supply which is currently maintained by the Civil Engineering Services Directorate: Water and Sanitation Department of George Municipality.

5.2 Institutional Training Requirements

No specific institutional training is required as the project components are similar to existing infrastructure already being maintained by the Municipality.

5.3 Cost Recovery Plan


There is currently no cost recovery on this scheme. Operations and maintenance costs will be funded from their own funds.

6 Capital Cost Estimate


7 Conclusion and Recommendations

1. The George Municipality needs to upgrade the existing Thembaletu sewer pumpstation No. 6 and associated rising main due to it being overloaded and exceeding its capacity on a regular basis. The current capacity of the pumpstation is 60 ℓ/s and needs to be upgraded to cater for future flows for the next 20 years of 238 ℓ/s . In terms of the sanitation master plan of the George Municipality, further upgrades to the pumpstation will need to be carried out in the future to cater for the ultimate capacity of 400 ℓ/s as per the GMSMP.
2. The upgrades include the addition of a $\varnothing 400\text{mm}$ rising main, to be installed parallel to the existing $\varnothing 250\text{mm}$ rising main for rounded 710m from the control chamber at the pump station. At a later date, a second $\varnothing 400\text{mm}$ rising main can be installed parallel to the newly proposed $\varnothing 400\text{mm}$ rising main. This can replace the existing $\varnothing 250\text{mm}$ rising main if George Municipality wishes to remove the existing $\varnothing 250\text{mm}$ rising main. The two rising mains will be used in conjunction in future to accommodate the 400 ℓ/s flow requirement. The layout of the pump station, therefore, was carefully considered to be compatible with both the current upgrades, as well as future planned upgrades.
3. The Environmental Impact Assessment (EIA) and Water Use License Application (WULA) were concluded in 2014 and the environmental authorisation is still valid and encompasses all the activities triggered. SMEC will incorporate the terms and conditions of the authorization in the design of the project.
4. The pump station was designed with the space allowance for 3 pumps to be installed initially (each with a 134 ℓ/s capacity) to meet the initial requirement of 238 ℓ/s with a standby pump; as well as allowing sufficient space to install an additional pump in the future to meet the final demand of 400 ℓ/s . This configuration will ensure that there is always standby availability for the pumps if any of the pumps have a failure or need maintenance. The pumps will be controlled with VSDs to reduce electrical load, minimize the transient events during normal operations and provide various flow regimes.
5. The additional electrical load requirements with the upgrading of the pumpstation required the electrical control, switchgear and backup power generation to be increased and upgraded. It is recommended that the spare 11kV feeder on the existing 3-way RMU be used to bring in an alternative supply to the pump station, in order to provide a redundant ring feed supply, thereby ensuring a more reliable source of bulk supply. It should be noted that an existing transformer is an oil-filled unit, which does pose a fire risk, especially when installed in a dedicated room (as is the current case). With open cable trenches, protruding to the other rooms, the risk of burning transformer oil being spread quickly throughout the entire building is a major fire hazard. For this reason, it is recommended that the new transformers be of the dry-type (vacuum pressure-impregnated cast-resin).
6. Based on the new pumps and associated equipment to be installed as part of the upgrade for each of the two (2) sumps, it is recommended that a dedicated new MCC be installed for each sump's equipment.
7. SMEC recommend that an **800 kVA generator (640 kW prime rated)** be considered instead of the 1.5MVA included in the initial scope of work as set out in the RFQ, as this would be a much better-suited rating for this specific application.
8. The alignment of the rising main will follow the alignments of the existing 250mm diameter pipeline crossing the existing pipe bridge where allowance has been made to discharge into the receiving manhole at the end of the upgrade route.


Annexure A **Pump Station Drawings**




SECTION 2-2



LEVEL 0 SITE PLAN
FLOW METER
CHAMBER



SECTION 7-7
1:50




SECTION 6-6
1:50


  		PRELIMINARY GEORGE MUNICIPALITY THEMBALETHU PUMP STATION FLOW METER CHAMBER		DRAWN BY C/284	CHECKED BY P.S.	DESIGNED BY 000	REVISION 2
SCALE 1:50 SCALE 1:50 SCALE 1:50		PROJECT APPROVED ENGINEER PE ENG. INC. SIGNATURE		PROJECT MANAGER T. COOMBE PROJECT DIRECTOR		PROJECT MANAGER T. COOMBE	




PUMP STATION EAST
ELEVATION




PUMP STATION
NORTH ELEVATION



PUMP STATION
SOUTH ELEVATION





LEVEL 0 SITE PLAN
1:100

1	DATE	2	PROJECT / SYSTEM DESCRIPTION	3	APPROVED T.S.	4	SEAL	5	OWNER APPROVAL	6	SCALE	7	SCALE	8	SCALE	9	SCALE	10	SCALE	11	SCALE	12	SCALE	13	SCALE	14	SCALE	15	SCALE	16	SCALE	17	SCALE	18	SCALE	19	SCALE	20	SCALE	21	SCALE	22	SCALE	23	SCALE	24	SCALE	25	SCALE	26	SCALE	27	SCALE	28	SCALE	29	SCALE	30	SCALE	31	SCALE	32	SCALE	33	SCALE	34	SCALE	35	SCALE	36	SCALE	37	SCALE	38	SCALE	39	SCALE	40	SCALE	41	SCALE	42	SCALE	43	SCALE	44	SCALE	45	SCALE	46	SCALE	47	SCALE	48	SCALE	49	SCALE	50	SCALE	51	SCALE	52	SCALE	53	SCALE	54	SCALE	55	SCALE	56	SCALE	57	SCALE	58	SCALE	59	SCALE	60	SCALE	61	SCALE	62	SCALE	63	SCALE	64	SCALE	65	SCALE	66	SCALE	67	SCALE	68	SCALE	69	SCALE	70	SCALE	71	SCALE	72	SCALE	73	SCALE	74	SCALE	75	SCALE	76	SCALE	77	SCALE	78	SCALE	79	SCALE	80	SCALE	81	SCALE	82	SCALE	83	SCALE	84	SCALE	85	SCALE	86	SCALE	87	SCALE	88	SCALE	89	SCALE	90	SCALE	91	SCALE	92	SCALE	93	SCALE	94	SCALE	95	SCALE	96	SCALE	97	SCALE	98	SCALE	99	SCALE	100	SCALE
1	DATE	2	PROJECT / SYSTEM DESCRIPTION	3	APPROVED T.S.	4	SEAL	5	OWNER APPROVAL	6	SCALE	7	SCALE	8	SCALE	9	SCALE	10	SCALE	11	SCALE	12	SCALE	13	SCALE	14	SCALE	15	SCALE	16	SCALE	17	SCALE	18	SCALE	19	SCALE	20	SCALE	21	SCALE	22	SCALE	23	SCALE	24	SCALE	25	SCALE	26	SCALE	27	SCALE	28	SCALE	29	SCALE	30	SCALE	31	SCALE	32	SCALE	33	SCALE	34	SCALE	35	SCALE	36	SCALE	37	SCALE	38	SCALE	39	SCALE	40	SCALE	41	SCALE	42	SCALE	43	SCALE	44	SCALE	45	SCALE	46	SCALE	47	SCALE	48	SCALE	49	SCALE	50	SCALE	51	SCALE	52	SCALE	53	SCALE	54	SCALE	55	SCALE	56	SCALE	57	SCALE	58	SCALE	59	SCALE	60	SCALE	61	SCALE	62	SCALE	63	SCALE	64	SCALE	65	SCALE	66	SCALE	67	SCALE	68	SCALE	69	SCALE	70	SCALE	71	SCALE	72	SCALE	73	SCALE	74	SCALE	75	SCALE	76	SCALE	77	SCALE	78	SCALE	79	SCALE	80	SCALE	81	SCALE	82	SCALE	83	SCALE	84	SCALE	85	SCALE	86	SCALE	87	SCALE	88	SCALE	89	SCALE	90	SCALE	91	SCALE	92	SCALE	93	SCALE	94	SCALE	95	SCALE	96	SCALE	97	SCALE	98	SCALE	99	SCALE	100	SCALE
1	DATE	2	PROJECT / SYSTEM DESCRIPTION	3	APPROVED T.S.	4	SEAL	5	OWNER APPROVAL	6	SCALE	7	SCALE	8	SCALE	9	SCALE	10	SCALE	11	SCALE	12	SCALE	13	SCALE	14	SCALE	15	SCALE	16	SCALE	17	SCALE	18	SCALE	19	SCALE	20	SCALE	21	SCALE	22	SCALE	23	SCALE	24	SCALE	25	SCALE	26	SCALE	27	SCALE	28	SCALE	29	SCALE	30	SCALE	31	SCALE	32	SCALE	33	SCALE	34	SCALE	35	SCALE	36	SCALE	37	SCALE	38	SCALE	39	SCALE	40	SCALE	41	SCALE	42	SCALE	43	SCALE	44	SCALE	45	SCALE	46	SCALE	47	SCALE	48	SCALE	49	SCALE	50	SCALE	51	SCALE	52	SCALE	53	SCALE	54	SCALE	55	SCALE	56	SCALE	57	SCALE	58	SCALE	59	SCALE	60	SCALE	61	SCALE	62	SCALE	63	SCALE	64	SCALE	65	SCALE	66	SCALE	67	SCALE	68	SCALE	69	SCALE	70	SCALE	71	SCALE	7																																																									



PROJECT: TEL C064	PHASE: P5	WORKING DRAWING: 002	REVISION: 2
----------------------	--------------	-------------------------	----------------


Annexure B **Mechanical Drawings**

REVISIONS		NO.	DATE	DESCRIPTION	INITIAL	CHECKED	TA	DATE	DRAWN	CHECKED	TB	DESIGNED	TB	DESIGNED	TA	DATE	SIGNED	SMC SOUTH AFRICA	 Member of the Sellen Group GEORGE PROFESSIONAL CONSULTANTS  GEORGE PROFESSIONAL CONSULTANTS		SIGNED _____ DATE _____		SIGNED _____ DATE _____		PROVISION OF PROFESSIONAL SERVICES FOR UPGRADING OF THEMBALETHU No. 6 SEWER PUMP STATION		LAYOUT OF MECHANICAL SCREENING EQUIPMENT		SIZE A1	SCALE 1:50	PROJECT DRAWING NUMBER C-1034	MECH 001	SHEET No. 1	REV 1	1	1
-----------	--	-----	------	-------------	---------	---------	----	------	-------	---------	----	----------	----	----------	----	------	--------	------------------	---	--	----------------------------	--	----------------------------	--	--	--	---	--	------------	---------------	----------------------------------	-------------	----------------	----------	---	---

[illegible]

Annexure C **Structural Drawings**

NOTES:
1. DARK GREY = EXISTING STRUCTURE




ISOMETRIC LAYOUT

[illegible]

1. REFER TO DRAWING C19A-11-DMS-001 TO 003 FOR GENERAL NOTES
2. REFER TO DRAWING C19A-11-DCA-109 FOR TYPICAL CONCRETE DETAILS
3. REFER TO DRAWING C19A-11-DMA-110 FOR TYPICAL MASONRY DETAILS
4. REFER TO DRAWING C19A-11-DST-111 TO 112 FOR TYPICAL STEEL DETAILS
5. REINFORCE TO BE SUPPLIED IN EVERY 4TH BRICK COURSE FOR ALL MASONRY ELEMENTS ABOVE & BELOW SURFACE BED LEVEL
6. BRICKWORK SETTING OUT AS PER LAYOUTS
7. ALLOWABLE BEARING PRESSURE = 150KPa
8. ALL BUILDING WORK AND MATERIALS ARE TO COMPLY WITH LOCAL AUTHORITY'S REQUIREMENTS AND ARE TO BE IN ACCORDANCE WITH SANS 10400 NATIONAL BUILDING REGULATIONS.
9. ALL DIMENSIONS TO BE VERIFIED ON SITE PRIOR TO START OF CONSTRUCTION. ANY DISCREPANCIES TO BE REPORTED TO THE ENGINEER.

ELEMENT NOMENCLATURE


ELEMENT	LEVEL	ELEMENT No
E-BEAM	E-BEAMENT	001-999
E-FOUNDATION	F-FOUNDATION	
E-COLUMN	G-COLUMN	
E-FOOTING	G-FOOTING	
E-GROUND	G-GROUND	
E-PENETRATION	1-9 LEVELS OR FLOORS HIGHER UP	
E-STAIR		
E-WALL		



- NOTES:
- REFER TO DRAWING C1924-1-DNS-001 TO 003 FOR GENERAL NOTES.
 - REFER TO DRAWING C1934-1-DQM-110 FOR TYPICAL CONCRETE DETAILS.
 - REFER TO DRAWING C1934-1-DMA-111 FOR TYPICAL MASONRY DETAILS.
 - REFER TO DRAWING C1934-1-DST-112 FOR TYPICAL STEEL DETAILS.
 - BRICKWORK TO BE SUPPLIED IN EVERY 4TH BRICK COURSE FOR ALL MASONRY ELEMENTS ABOVE & BELOW SURFACE BED LEVEL.
 - BRICKWORK SETTING OUT AS PER LAYOUTS.
 - ALLOWABLE BEARING PRESSURE = 150MPa.
 - ALL BUILDING WORK AND MATERIALS ARE TO COMPLY WITH LOCAL AUTHORITY'S REQUIREMENTS AND ARE TO BE IN ACCORDANCE WITH SANS 10400 NATIONAL BUILDING REGULATIONS.


LEGEND
ELEMENT NOMENCLATURE

ELEMENT	LEVEL	ELEMENT No.
B-BASEMENT		001-999
B-BEAM		
C-COLUMN		
F-FOUNDATION		
G-GROUND		
P-PENETRATION		
S-STAIR		
W-WALL		



LEVEL -1 COLUMN LAYOUT



SCALE 1:100



LEVEL 1 COLUMN LAYOUT

SCALE 1:100

PRELIMINARY GEORGE MUNICIPALITY THEMBALETHU PUMP STATION STRUCTURAL DRAWING COLUMN LAYOUT		CLIENT GEORGE THE CITY OF FALLES BRANSON	REVISION SABC 1.0 2.0 3.0 4.0 5.0	SCALE 1:100 SCALE 1:100 SCALE 1:100 SCALE 1:100	DRAWING APPROVED ENGINEER PROJECT MANAGER SENIOR ENGINEER SENIOR ENGINEER SENIOR ENGINEER SENIOR ENGINEER	NAME T. SIBHE R. SIBHE T. SIBHE R. SIBHE R. SIBHE R. SIBHE	TITLE QUANTITY CHECK QUANTITY CHECK QUANTITY CHECK QUANTITY CHECK QUANTITY CHECK QUANTITY CHECK	DATE 15/01/2023 15/01/2023 15/01/2023 15/01/2023 15/01/2023 15/01/2023	PROJECT / DRAWING NO. PRELIMINARY 15/01/2023	SHEET NO. 1	SHEET TYPE SCA	SHEET NUMBER 103	SHEET A
--	--	--	---	--	---	--	---	--	--	----------------	-------------------	---------------------	---------



1. REFER TO DRAWING C934+DMS-001 TO 003 FOR GENERAL NOTES.
2. REFER TO DRAWING C934+DQN-009 FOR TYPICAL CONCRETE DETAILS.
3. REFER TO DRAWING C934+DMA-110 FOR TYPICAL MASONRY DETAILS.
4. REFER TO DRAWING C934+DST-111 TO 112 FOR TYPICAL STEEL DETAILS.
5. COURSE FOR ALL MASONRY ELEMENTS ABOVE AND BELOW SURFACE BED LEVEL.
6. BRICKWORK SETTING OUT AS PER LAYOUTS.
7. ALLOWABLE BEARING PRESSURE = 50NPA.
8. ALL BUILDING WORK AND MATERIALS ARE TO COMPLY WITH LOCAL AUTHORITY'S REQUIREMENTS AND ARE TO BE IN ACCORDANCE WITH SANS 10400 NATIONAL BUILDING REGULATIONS.
9. ALL DIMENSIONS TO BE VERIFIED ON SITE PRIOR TO START OF CONSTRUCTION. ANY DISCREPANCIES TO BE REPORTED TO THE ENGINEER.

LEGEND


ELEMENT: E-BEAM
E-COLUMN
F-FOOTING
P-PENETRATION
S-STAIR
W-WALL

LEVEL: B-BASEMENT
F-FOUNDATION
G-GROUND
1-9 LEVELS OR FLOORS HIGHER UP

ELEMENT NO.: 001-999

$[W] - [1] - [001]$

1. SAW-CUT JOINTS OR KEYED CONSTRUCTION JOINTS AT A MAXIMUM SPACING 30x SLAB THICKNESS OR 4500mm WHICHEVER IS LESSER (SEE TYPICAL DETAIL).
2. MESH DISCONTINUING OVER JOINTS: (SEE TYPICAL DETAIL)
3. RECTANGULAR SAW-CUT PANEL ASPECT RATIO TO BE NOT MORE THAN 1:25



- ## LEGEND



```

graph TD
    Level{LEVEL}
    Element[ELEMENT]
    ElemNo[ELEMENT NO.]

    Level -- E-BEAM --> ElemNo_001_999_1[001-999]
    Level -- E-FOUNDATION --> ElemNo_001_999_1
    Level -- E-COLUMN --> ElemNo_001_999_1
    Level -- E-FOOTING --> ElemNo_001_999_1
    Level -- F-PENETRATION --> ElemNo_001_999_1
    Level -- S-STAIR --> ElemNo_001_999_1
    Level -- W-WALL --> ElemNo_001_999_1
    Level -- 1-9 LEVELS OR FLOORS HIGHER UP --> CalcBox["[W] - [1] - [001]"]
    CalcBox --> ElemNo_001_999_1
  
```


[illegible]

1. REFER TO DRAWING C1924-1-DMS-001 TO 003 FOR GENERAL NOTES.
2. REFER TO DRAWING C1934-1-DCM-109 FOR TYPICAL CONCRETE DETAILS.
3. REFER TO DRAWING C1934-1-DM-110 FOR TYPICAL MASONRY DETAILS.
4. REFER TO DRAWING C1934-1-DST-111 TO 112 FOR TYPICAL STEEL DETAILS.
5. COURSE FOR BE SUPPLIED IN EVERY 4TH BRICK. COMPLIANCE FOR ALL MASONRY ELEMENTS ABOVE & BELOW SURFACE BED LEVEL.
6. BRICKWORK SETTING OUT AS PER LAYOUTS.
7. ALLOWABLE BEARING PRESSURE = 150MPa.
8. ALL BUILDING WORK AND MATERIALS ARE TO COMPLY WITH LOCAL AUTHORITY'S REQUIREMENTS AND ARE TO BE IN ACCORDANCE WITH SANS 10400 NATIONAL BUILDING REGULATIONS.
9. ALL DIMENSIONS TO BE VERIFIED ON SITE PRIOR TO START OF CONSTRUCTION. ANY DISCREPANCIES TO BE REPORTED TO THE ENGINEER.




SECTION B-B

SCALE 1:50



TRUSS 1

SCALE 1:50













TRUSS 2

SCALE 1:50

[illegible]




NOTE:

1. REFER TO DRAWING C192L-1-DNS-001 TO 063 FOR GENERAL NOTES.
2. REFER TO DRAWINGS C1924-1-DCN-103 TO 105 FOR CONCRETE LAYOUTS.
3. REFER TO DRAWINGS C1924-1-DCN-106 FOR MASONRY LAYOUTS.
4. REFER TO DRAWING C1932-1-DST-407 & 408 FOR STEEL ELEVATIONS & SECTIONS.




1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100	101	102	103	104	105	106	107	108	109	110	111	112	113	114	115	116	117	118	119	120	121	122	123	124	125	126	127	128	129	130	131	132	133	134	135	136	137	138	139	140	141	142	143	144	145	146	147	148	149	150	151	152	153	154	155	156	157	158	159	160	161	162	163	164	165	166	167	168	169	170	171	172	173	174	175	176	177	178	179	180	181	182	183	184	185	186	187	188	189	190	191	192	193	194	195	196	197	198	199	200	201	202	203	204	205	206	207	208	209	210	211	212	213	214	215	216	217	218	219	220	221	222	223	224	225	226	227	228	229	230	231	232	233	234	235	236	237	238	239	240	241	242	243	244	245	246	247	248	249	250	251	252	253	254	255	256	257	258	259	260	261	262	263	264	265	266	267	268	269	270	271	272	273	274	275	276	277	278	279	280	281	282	283	284	285	286	287	288	289	290	291	292	293	294	295	296	297	298	299	300	301	302	303	304	305	306	307	308	309	310	311	312	313	314	315	316	317	318	319	320	321	322	323	324	325	326	327	328	329	330	331	332	333	334	335	336	337	338	339	340	341	342	343	344	345	346	347	348	349	350	351	352	353	354	355	356	357	358	359	360	361	362	363	364	365	366	367	368	369	370	371	372	373	374	375	376	377	378	379	380	381	382	383	384	385	386	387	388	389	390	391	392	393	394	395	396	397	398	399	400	401	402	403	404	405	406	407	408	409	410	411	412	413	414	415	416	417	418	419	420	421	422	423	424	425	426	427	428	429	430	431	432	433	434	435	436	437	438	439	440	441	442	443	444	445	446	447	448	449	450	451	452	453	454	455	456	457	458	459	460	461	462	463	464	465	466
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----


- NOTE:
1. REFER TO DRAWING C192L-LDMS-001 TO 063 FOR REBAR DETAILS.
 2. REFER TO DRAWINGS L197L-L1LH-003 TO 055 FOR CONCRETE LAYOUTS.
 3. REFER TO DRAWINGS C192L-L1LH-056 FOR MASONRY LAYOUTS.
 4. REFER TO DRAWING C732-L1D1-007 & 008 FOR STEEL FIXATIONS & SECTIONS.



270mm WIDE CAVITY WALL
SCALE 1:20




TYPICAL INTERNAL ISOLATION JOINT
SCALE 1:10




SURFACE BED DEPTH (mm)	SAW CUT DEPTH (mm)
80	20
100	25
125	35
150	45
180	45
200	50


TYPICAL SAW CUT JOINT DETAIL (S.C.J)
SCALE 1:5




TYPICAL SURFACE BED ISOLATION JOINT AT DOORWAYS
SCALE 1:10




TYPICAL MESH AT JOINT DETAIL
SCALE 1:10



TYPICAL EXPANSION JOINT DETAIL
SCALE 1:5



SURFACE BED LAYER WORKS SPECIFICATIONS
SCALE 1:20



TYPICAL MESH AT JOINT DETAIL
SCALE 1:10


FOR APPROVAL GEORGE MUNICIPALITY THEBALEHU PUMP STATION STRUCTURAL DRAWING TYPICAL DETAILS		DATE: 11/01/2024 SCALE: 1:50 PROJECT NO: 1924
APPROVED BY: [Signature] DATE: 11/01/2024		APPROVED BY: [Signature] DATE: 11/01/2024
APPROVED BY: [Signature] DATE: 11/01/2024		APPROVED BY: [Signature] DATE: 11/01/2024

1.	REFER TO DRAWING C1934-1-DMS-001 TO 003 FOR GENERAL NOTES.
2.	REFER TO DRAWING C1934-1-DCR-113 TO 115 FOR CONCRETE DETAILS.
3.	REFER TO DRAWING C1934-1-DCR-109 FOR TYPICAL CONCRETE DETAILS.
4.	REFER TO DRAWING C1934-1-DMW-110 FOR TYPICAL MASONRY DETAILS.
5.	REFER TO DRAWING C1934-1-DST-111 TO 112 FOR TYPICAL STEEL DETAILS.
6.	BRICK SHALL BE SUPPLIED IN EVERY 4TH BRICK COURSE FOR ALL MASONRY ELEMENTS ABOVE & BE SURFACE BED LEVEL.
7.	ALLOWABLE SETTING OUT AS PER LAYOUTS.
8.	ALLOWABLE BEARING PRESSURE = 150KPa.
9.	ALL BUILDING WORK AND MATERIALS ARE TO COMPLY WITH LOCAL AUTHORITY'S REQUIREMENTS AND ARE TO BE IN ACCORDANCE WITH SANS 10400 NATIONAL BUILDING REGULATIONS.

ELEMENT:	LEVEL:
1.1	1.1
1.2	1.2
1.3	1.3
1.4	1.4
1.5	1.5
1.6	1.6
1.7	1.7
1.8	1.8
1.9	1.9
1.10	1.10
1.11	1.11
1.12	1.12
1.13	1.13
1.14	1.14
1.15	1.15
1.16	1.16
1.17	1.17
1.18	1.18
1.19	1.19
1.20	1.20
1.21	1.21
1.22	1.22
1.23	1.23
1.24	1.24
1.25	1.25
1.26	1.26
1.27	1.27
1.28	1.28
1.29	1.29
1.30	1.30
1.31	1.31
1.32	1.32
1.33	1.33
1.34	1.34
1.35	1.35
1.36	1.36
1.37	1.37
1.38	1.38
1.39	1.39
1.40	1.40
1.41	1.41
1.42	1.42
1.43	1.43
1.44	1.44
1.45	1.45
1.46	1.46
1.47	1.47
1.48	1.48
1.49	1.49
1.50	1.50
1.51	1.51
1.52	1.52
1.53	1.53
1.54	1.54
1.55	1.55
1.56	1.56
1.57	1.57
1.58	1.58
1.59	1.59
1.60	1.60
1.61	1.61
1.62	1.62
1.63	1.63
1.64	1.64
1.65	1.65
1.66	1.66
1.67	1.67
1.68	1.68
1.69	1.69
1.70	1.70
1.71	1.71
1.72	1.72
1.73	1.73
1.74	1.74
1.75	1.75
1.76	1.76
1.77	1.77
1.78	1.78
1.79	1.79
1.80	1.80
1.81	1.81
1.82	1.82
1.83	1.83
1.84	1.84
1.85	1.85
1.86	1.86
1.87	1.87
1.88	1.88
1.89	1.89
1.90	1.90
1.91	1.91
1.92	1.92
1.93	1.93
1.94	1.94
1.95	1.95
1.96	1.96
1.97	1.97
1.98	1.98
1.99	1.99
2.00	2.00
2.01	2.01
2.02	2.02
2.03	2.03
2.04	2.04
2.05	2.05
2.06	2.06
2.07	2.07
2.08	2.08
2.09	2.09
2.10	2.10
2.11	2.11
2.12	2.12
2.13	2.13
2.14	2.14
2.15	2.15
2.16	2.16
2.17	2.17
2.18	2.18
2.19	2.19
2.20	2.20
2.21	2.21
2.22	2.22
2.23	2.23
2.24	2.24
2.25	2.25
2.26	2.26
2.27	2.27
2.28	2.28
2.29	2.29
2.30	2.30
2.31	2.31
2.32	2.32
2.33	2.33
2.34	2.34
2.35	2.35
2.36	2.36
2.37	2.37
2.38	2.38
2.39	2.39
2.40	2.40
2.41	2.41
2.42	2.42
2.43	2.43
2.44	2.44
2.45	2.45
2.46	2.46
2.47	2.47
2.48	2.48
2.49	2.49
2.50	2.50
2.51	2.51

ELEMENT	LEVEL	ELEMENT No.
W-WALL	1-9 LEVELS OR FLOORS HIGHER UP	001-999
S-STAR		
P-PENETRATION		
F-FOOTING		
C-COLUMN		
E-BEAM		
B-BASEMENT		

1. SAW-CUT JOINTS OR KEYED CONSTRUCTION JOINTS AT A MAXIMUM SPACING 30x SLAB THICKNESS OR 4500mm WHICHEVER IS LESSER (SEE TYPICAL DETAIL).
2. MESH DISCONTINUING OVER JOINTS. (SEE TYPICAL DETAIL)
3. RECTANGULAR SAW-CUT PANEL ASPECT RATIO TO BE NOT MORE THAN 11:25



GEORGE MUNICIPALITY
THEMBALETHU PUMP STATION

TRAINING WALL AND CHAMBER LAYOUTS

FIGURE	DRAWING TYPE	REVISION
1	D.C.H	116



QUALITY



EELS AT AN AT SIZE FANBEAM	
1.1	1.1 1.2 1.3 1.4 1.5

Figure 1 consists of two horizontal bar charts. The top chart is for Scale 11 and the bottom chart is for Scale 131. Both charts have a vertical axis with response categories 1, 2, 3, 4, and 5. The horizontal axis represents the percentage of respondents, ranging from 0 to 100. For Scale 11, the percentages are approximately: 1 (10%), 2 (10%), 3 (10%), 4 (40%), and 5 (30%). For Scale 131, the percentages are approximately: 1 (60%), 2 (30%), 3 (10%), 4 (5%), and 5 (5%).

1500007 2016

PROJECT	RAFTER	T. BOWNE
PROJECT	RAFTING CHECK	R. PETERS
PROJECT	DESIGNER	T. BOWNE
PROJECT	DESIGN CHECK	R. PETERS
PROJECT	PROJECT MANAGER	T. BOWNE
PROJECT	PROJECT DIRECTOR	T. BOWNE



APPENDIX

ARGUMENT & REVIEW DESCRIPTION

PRELIMINARY

11

12.11.2023	
------------	--



SCALE 1:50

MUNICIPALITY PUMP STATION RAL DRAWING AND CHAMBER SECTIONS	PLANT SHEET 115	REVISION e
--	---	--------------------------------------


FRAMING TYPE	FRAMING THREE
--------------	---------------

10. FULL CHARGES TO BE PERMITTED PRIOR TO THE START OF CONSTRUCTION. ANY DISCREPANCIES TO BE REPORTED TO THE ENGINEER.

1. REFER TO CRAWINGS 1924-1-DNS-201 TO 063 FOR GENERAL NOTES.
2. REFER TO CRAWINGS 1924-1-DN-103 TO 105 FOR CONTRAF LAYOUTS.
3. REFER TO CRAWINGS 1924-1-DN-136 FOR MASONRY LAYOUTS.
4. REFER TO CRAWINGS C-732-1-DST-107 & 108 FOR STEEL ELEVATIONS & SECTIONS.



400mm WIDE REINFORCED CONCRETE RETAINING WALL



TYPICAL SUBSOL DETAIL

200	201	202	203	204	205	206	207	208	209	210	211	212	213	214	215	216	217	218	219	220	221	222	223	224	225	226	227	228	229	230	231	232	233	234	235	236	237	238	239	240	241	242	243	244	245	246	247	248	249	250	251	252	253	254	255	256	257	258	259	260	261	262	263	264	265	266	267	268	269	270	271	272	273	274	275	276	277	278	279	280	281	282	283	284	285	286	287	288	289	290	291	292	293	294	295	296	297	298	299	300	301	302	303	304	305	306	307	308	309	310	311	312	313	314	315	316	317	318	319	320	321	322	323	324	325	326	327	328	329	330	331	332	333	334	335	336	337	338	339	340	341	342	343	344	345	346	347	348	349	350	351	352	353	354	355	356	357	358	359	360	361	362	363	364	365	366	367	368	369	370	371	372	373	374	375	376	377	378	379	380	381	382	383	384	385	386	387	388	389	390	391	392	393	394	395	396	397	398	399	400	401	402	403	404	405	406	407	408	409	410	411	412	413	414	415	416	417	418	419	420	421	422	423	424	425	426	427	428	429	430	431	432	433	434	435	436	437	438	439	440	441	442	443	444	445	446	447	448	449	450	451	452	453	454	455	456	457	458	459	460	461	462	463	464	465	466	467	468	469	470	471	472	473	474	475	476	477	478	479	480	481	482	483	484	485	486	487	488	489	490	491	492	493	494	495	496	497	498	499	500	501	502	503	504	505	506	507	508	509	510	511	512	513	514	515	516	517	518	519	520	521	522	523	524	525	526	527	528	529	530	531	532	533	534	535	536	537	538	539	540	541	542	543	544	545	546	547	548	549	550	551	552	553	554	555	556	557	558	559	560	561	562	563	564	565	566	567	568	569	570	571	572	573	574	575	576	577	578	579	580	581	582	583	584	585	586	587	588	589	590	591	592	593	594	595	596	597	598	599	600	601	602	603	604	605	606	607	608	609	610	611	612	613	614	615	616	617	618	619	620	621	622	623	624	625	626	627	628	629	630	631	632	633	634	635	636	637	638	639	640	641	642	643	644	645	646	647	648	649	650	651	652	653	654	655	656	657	658	659	660	661	662	663	664	665	666	667	668	669	670	671	672	673	674	675	676	677	678	679	680	681	682	683	684	685	686	687	688	689	690	691	692	693	694	695	696	697	698	699	700	701	702	703	704	705	706	707	708	709	710	711	712	713	714	715	716	717	718	719	720	721	722	723	724	725	726	727	728	729	730	731	732	733	734	735	736	737	738	739	740	741	742	743	744	745	746	747	748	749	750	751	752	753	754	755	756	757	758	759	760	761	762	763	764	765	766	767	768	769	770	771	772	773	774	775	776	777	778	779	780	781	782	783	784	785	786	787	788	789	790	791	792	793	794	795	796	797	798	799	800	801	802	803	804	805	806	807	808	809	810	811	812	813	814	815	816	817	818	819	820	821	822	823	824	825	826	827	828	829	830	831	832	833	834	835	836	837	838	839	840	841	842	843	844	845	846	847	848	849	850	851	852	853	854	855	856	857	858	859	860	861	862	863	864	865	866	867	868	869	870	871	872	873	874	875	876	877	878	879	880	881	882	883	884	885	886	887	888	889	890	891	892	893	894	895	896	897	898	899	900	901	902	903	904	905	906	907	908	909	910	911	912	913	914	915	916	917	918	919	920	921	922	923	924	925	926	927	928	929	930	931	932	933	934	935	936	937	938	939	940	941	942	943	944	945	946	947	948	949	950	951	952	953	954	955	956	957	958	959	960	961	962	963	964	965	966	967	968	969	970	971	972	973	974	975	976	977	978	979	980	981	982	983	984	985	986	987	988	989	990	991	992	993	994	995	996	997	998	999	1000
										SMC PROJECT NO. 1924										SMC										SABS										GEORGE MUNICIPALITY										THERIALEHU PEAK STATION										STATION TRAIN IN5										CONCRETE TYPICAL DETAILS										GEORGE MUNICIPALITY																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																


[illegible][illegible]

1.	REFI JFN
2.	REFI JON
3.	REFI MAS
4.	REFI STE


- | | | | | | | | | | | | |
|----|------|-----|----|------|-----|----|------|-----|----|------|-----|
| 1. | REFE | JFN | 2. | REFE | JUN | 3. | REFE | MAS | 4. | REFE | STE |
|----|------|-----|----|------|-----|----|------|-----|----|------|-----|




PURLIN SPLICE CONNECTION




DETAIL
SCALE 1:10




DETAIL
SCALE '20



TYPICAL 1/2 KNEE BRACING CONNECTION



DETAIL
SCALE '20




TYPICAL KNEE BRACING CONNECTION



DETAIL
SCALE 1/20
DT-C4
TYPE





ELEVATION




DETAIL
SCALE 1:10



ELEVATION



CORNER CROSS BRACING TO TRUSS CONNECTION




Technical drawing of a window assembly cross-section. The drawing shows a window frame with a glass pane and various seals and components. Dimensions are provided in millimeters (mm) and inches (in). Key components labeled include:


- 55-5006 ELA**: A seal or gasket.
- 2.04x48 88 HFE**: A component, possibly a hinge or fastener.
- 30x250x6mm THICK GUSSET PLATE**: A structural plate.
- BOTTOM OF THE TOP CHORD ST-52**: The bottom edge of the top chord.
- CFL PURLIN**: A component at the bottom of the assembly.
- 75x106 ELA TRUSS TCP CHORD**: A truss component.

Dimensions shown include:


- A vertical dimension of **202** mm.
- A horizontal dimension of **55** mm.
- An angle of **9°**.
- A distance of **65** mm from the vertical centerline to the start of the angled section.
- A distance of **45** mm along the angled section.
- A distance of **10** mm between two points on the angled section.
- An angle of **1.49°** at the base of the angled section.
- A total width dimension of **567** mm at the bottom.




CRANE BEAM TO CONCRETE ROOF SLAB CONNECTION

[illegible]

CROSS BRACING TO CROSS BRACING

[illegible]

NOTE:
 1. REFER TO DRAWING C192-1-D-S-001 TO 003 FOR GENERAL NOTES.
 2. REFER TO DRAWINGS C192-1-D-CN-003 TO 105 FOR LONCH & LANCIS.
 3. REFER TO DRAWINGS C192-1-D-CN-008 FOR MASONRY LAYOUTS.
 4. REFER TO DRAWING C192-1-DST-007 & 008 FOR STEEL ELEVATIONS & SECTIONS.




TYPICAL STAIRCASE DETAIL

DETAIL
 SCALE 1/10

STAIRCASE TO CONCRETE CONNECTION

DETAIL
 SCALE 1/10




STAIRCASE BASEPLATE

DETAIL
 SCALE 1/10

CRANE BEAM TO COLUMN CONNECTION (ONE END ONLY)

DETAIL
 SCALE 1/10



CRANE BEAM TO COLUMN CONNECTION (ONE END ONLY)

DETAIL
 SCALE 1/10

PRELIMINARY


GEORGE MUNICIPALITY
 HERMANUS PUMP STATION

STILL ORAL URBAN RD
 STEEL TYPICAL DETAILS

DATE: 1/1/2020
 DRAWN BY: JLC
 CHECKED BY: JLC



SMEC PROJECT NO. 1924




NO.	REVISION	DATE	BY	CHKD.	APPD.
1	ISSUED FOR TENDERS	1/1/2020	JLC	JLC	JLC
2	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
3	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
4	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
5	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
6	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
7	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
8	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
9	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
10	FOR APPROVAL	1/1/2020	JLC	JLC	JLC

NO.	REVISION	DATE	BY	CHKD.	APPD.
1	ISSUED FOR TENDERS	1/1/2020	JLC	JLC	JLC
2	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
3	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
4	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
5	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
6	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
7	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
8	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
9	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
10	FOR APPROVAL	1/1/2020	JLC	JLC	JLC

NO.	REVISION	DATE	BY	CHKD.	APPD.
1	ISSUED FOR TENDERS	1/1/2020	JLC	JLC	JLC
2	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
3	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
4	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
5	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
6	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
7	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
8	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
9	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
10	FOR APPROVAL	1/1/2020	JLC	JLC	JLC

NO.	REVISION	DATE	BY	CHKD.	APPD.
1	ISSUED FOR TENDERS	1/1/2020	JLC	JLC	JLC
2	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
3	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
4	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
5	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
6	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
7	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
8	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
9	FOR APPROVAL	1/1/2020	JLC	JLC	JLC
10	FOR APPROVAL	1/1/2020	JLC	JLC	JLC



65 Regional Street
Sandton 2000
South Africa
900 Box 8012
Burgersfort 2012
South Africa
T 437 31 417 2500
F 437 31 417 2500
www.smecc.com

SABS
13 0 0 0 0 1

SMEC
Member of the SABS Group


GEORGE MUNICIPALITY
THEMBALETHU PUMP STATION

AS SHOWN
DRB

110
A

RC FOUNDATION REINFORCEMENT

CONCRETE COVER TO BASE:
50mm ALL ROUND

[illegible]

DEEL MEMBER	AANTAL NO OFF	PER DEEL/ MEMB.	DIA	LENGTE LENGTH	TOT.	MERK MARK	KODE CODE	BUIGING VOLGENS - SANS 282 BENDING TO - SANS 282				
								A	B	C	D	E/r
300x270/ 570x270 006,007	2	4 2 2 35 15	Y20 Y20 Y20 Y10 Y10	8600 3750 1650 1150 400	8 4 4 70 30	01 01a 01b S1 S2	37 37 37 207 207	140 140 350 240 210	(8490) (3640) (1330) 210 510			
270x270 008	1	4 20	Y16 Y10	3750 1100	4 20	02 S3	37 207	140 210	(3640) 210			
270x270 009	1	4 13	Y25 Y10	3750 1100	4 13	03 S4	37 207	140 210	(3640) 210			
270x270 010	1	4 16	Y20 Y10	3750 1100	4 16	04 S5	37 207	140 210	(3640) 210			
270x270 004	1	4 29	Y25 Y10	8600 1100	4 29	05 S6	37 207	140 210	(8490) 210			
270x270 001	1	4 36	Y20 Y10	8600 1100	4 36	06 S7	37 207	140 210	(8490) 210			
270x270 002	1	4 45	Y16 Y10	8600 1100	4 45	07 S8	37 207	140 210	(8490) 210			
570x270 003,005	2	4 2 36 36	Y20 Y12 Y10 Y10	8600 8650 1700 400	8 4 72 72	08 09 S9 S10	37 37 207 36	140 160 510 80	(8490) (8490) 210 60		210	60 (80)
270x270 011	1	4 4 14	Y20 Y20 Y10	1650 3000 1100	4 4 14	10 11 S13	37 37 207	350 140 210	(1330) (2920) 210			
CORBEL	6	4 3 1 3	Y16 Y10 Y10 Y10	2750 1700 1400 1100	24 18 6 18	S14 S15 S17 S16	188 207 207 207	800 210 210 210	520 520 380 225	250	200	360

[illegible]

DEEL MEMBER		AANTAL NO OFF	PER DEEL/ MEMB.	DIA	LENGTE LENGTH	TOT.	MERK MARK	KODE CODE	BUIGING VOLGENS - SANS 282 BENDING TO - SANS 282				
									A	B	C	D	E/r
B-2-004	1	2	Y20	4100	2	01	37	150	(4000)				
		2	Y20	6950	2	02	37	150	(6840)				
		2	Y12	4100	2	03	37	100	(4000)				
		2	Y12	6500	2	04	37	100	(6440)				
		2	Y20	6950	2	05	37	150	(6840)				
		2	Y20	4100	2	06	37	150	(4000)				
		31	Y10	1450	31	S1	60	440	210				
B-2-005	1	2	Y16	8550	2	07	37	150	(8450)				
		2	Y16	8850	2	08	20	(8850)					
		2	Y16	8600	2	09	37	150	(8490)				
		2	Y10	8350	2	10	37	100	(8250)				
		2	Y10	8450	2	11	20	(8440)					
		2	Y10	8400	2	12	37	100	(8290)				
		2	Y16	8550	2	13	37	150	(8450)				
		2	Y16	8850	2	14	20	(8850)					
		2	Y16	8600	2	15	37	150	(8490)				
		79	Y10	1450	79	S2	60	440	210				
B-2-006	1	2	Y16	5950	2	16	37	150	(5850)				
		2	Y16	11650	2	17	37	100	(11600)				
		2	Y10	5750	2	18	37	100	(5650)				
		2	Y10	11500	2	19	37	100	(11400)				
		2	Y16	8150	2	20	37	100	(8060)				
		2	Y16	9500	2	21	37	100	(9410)				
		53	Y10	1450	53	S3	60	440	210				
B-2-007	1	2	Y16	10050	2	22	38	120	9870	(120)			
		2	Y10	10050	2	23	38	100	9870	(100)			
		2	Y16	10050	2	24	38	120	9870	(120)			
		32	Y10	1450	32	S4	60	440	210				
B-2-008	1	2	Y16	10150	2	25	37	120	(10080)				
B-2-010		2	Y16	7500	2	26	37	120	(7390)				
		2	Y10	9950	2	27	37	100	(9880)				
		2	Y10	7300	2	28	37	100	(7190)				
		2	Y16	8150	2	29	37	100	(8060)				
		2	Y16	9500	2	30	37	100	(9410)				
		53	Y10	1450	53	S5	60	440	210				
B-2-011	1	4	Y16	7700	4	31	37	120	(7600)				
		4	Y10	7600	4	32	37	100	(7500)				
		4	Y16	7700	4	33	37	120	(7600)				
		45	Y10	1450	45	S6	60	440	210				